

BASELINE KPI REPORT

Prepared by –



Sub consultants



Submitted to -



LA SMART CITY

Contents

| | |
|---|----|
| List of tables..... | 4 |
| List of figures..... | 5 |
| Verification certificate | 6 |
| Executive Summary | 7 |
| Background of the study..... | 8 |
| Need of Smart Grid leading to Smart City | 8 |
| Objectives of the Smart Grid Project..... | 9 |
| Rourkela Smart Grid Leading to Smart City | 9 |
| Concept of AT&C losses | 12 |
| Methodology of verification | 13 |
| Field interviews..... | 13 |
| Methodology of sampling..... | 14 |
| Ring fencing & input points | 14 |
| Determination of ring fencing..... | 15 |
| Key maps of Rourkela Smart city..... | 15 |
| AT&C Loss verification (FY 2017-18)..... | 22 |
| 33 kV Input point feeder-wise losses | 23 |
| 11 kV Input point feeder-wise losses | 31 |
| Total Input energy into the smart city area | 38 |
| Billed energy booked under the smart city area | 38 |
| Billed units for HT consumers | 39 |
| Collection booked under the smart city area | 40 |
| AT&C Loss verification (FY 2018-19)..... | 43 |
| 33 kV Input point feeder-wise losses | 44 |
| 11 kV Input point feeder-wise losses | 53 |
| Total Input energy into the smart city area | 61 |
| Billed energy booked under the smart city area: | 62 |
| Billed units for HT consumers | 63 |
| Collection booked under the smart city area | 64 |
| Technical loss verification | 67 |
| Calculation of technical losses..... | 67 |
| 11 kV feeders | 73 |
| T&D loss for sample Distribution transformers..... | 87 |

| | |
|---|-----|
| System Reliability Indices..... | 88 |
| SAIFI (System Average Interruption Frequency Index) | 88 |
| SAIDI (System Average Interruption Duration Index) | 89 |
| Power Quality..... | 90 |
| Voltage profile..... | 90 |
| Power Factor profile..... | 92 |
| Harmonics profile | 94 |
| Voltage harmonics profile | 94 |
| Transformer failure rate..... | 112 |
| Rourkela Electrical Division (RED) transformer failure | 112 |
| Rourkela Sadar Electrical Division (RSED) transformer failure | 113 |
| Rourkela Sadar Electrical Division (RSED) transformer failure | 114 |
| Total transformer failure for FY 2017-18 | 115 |

List of tables

| | |
|--|----|
| Table 1 - Salient features of the distribution network of the smart city area..... | 11 |
| Table 2 - Category-wise consumer details under smart city area..... | 11 |
| Table 3 - List of officials visited | 13 |
| Table 4 - Methodology used for sampling | 14 |
| Table 5 - Standard resistance by conductor / cable type..... | 68 |
| Table 6 - Node-wise technical loss for DAV feeder | 74 |
| Table 7 - Node-wise technical loss for 11 kV BC feeder | 75 |
| Table 8 - Node-wise technical loss for 11 kV Jhirpani feeder | 77 |
| Table 9 - Node-wise technical loss for 11 kV Nayabazar feeder | 79 |
| Table 10 - Node-wise technical loss for 11 kV Plant site feeder | 81 |
| Table 11 - Node-wise technical loss for 11 kV ADE feeder | 83 |
| Table 12 - Node-wise technical loss for 11 kV Shaktinagar feeder..... | 85 |
| Table 13 - Node-wise technical loss for 11 kV PH road feeder | 86 |
| Table 14 - Summary of technical loss for sample 11 kV feeders | 87 |
| Table 15 - T&D loss for sample Distribution transformers | 87 |
| Table 16 - Interruption of supply -data from feeder metering system..... | 88 |
| Table 17 - Voltage profile of 33 kV feeders | 90 |
| Table 18 - Voltage profile of 11 kV feeders | 91 |
| Table 19 - Power factor profile of 33 kV feeders | 92 |
| Table 20 - Power factor profile of 11 kV feeders | 93 |
| Table 21 - Voltage harmonics profile | 94 |
| Table 22 - Current harmonics profile..... | 95 |

List of figures

| | |
|---|----|
| Figure 1 - List of Baseline KPIs covered under the project..... | 10 |
| Figure 2 - Methodology for verification..... | 13 |
| Figure 3 - 33 kV network configuration for FY 18-19..... | 15 |
| Figure 4 - Key map of smart city area..... | 16 |
| Figure 5 - Key map of part 1..... | 17 |
| Figure 6 - Key map of Part 2..... | 18 |
| Figure 7 - Key map of Part 3..... | 19 |
| Figure 8 - Key map of Part 4..... | 20 |
| Figure 9 - Key map of Part 4A..... | 21 |
| Figure 10 - SLD of 33 kV Basanti feeder..... | 68 |
| Figure 11 - SLD of 33 kV Chhend - Koelnagar feeder..... | 69 |
| Figure 12 - SLD of 33 kV Old IDC Civil township feeder..... | 70 |
| Figure 13 - SLD of 33 kV Powerhouse road (Town II) feeder..... | 71 |
| Figure 14 - SLD of 33 kV Industrial Estate feeder..... | 71 |
| Figure 15 - SLD of 33 kV Pilot project feeder..... | 72 |
| Figure 16 - Summary of Technical losses at 33 kV level..... | 73 |
| Figure 17 - SLD of 11 kV DAV feeder..... | 73 |
| Figure 18 - SLD of 11 kV BC Block feeder..... | 75 |
| Figure 19 - SLD of 11 kV Jhirpani feeder..... | 76 |
| Figure 20 - SLD of 11 kV Nayabazar feeder..... | 78 |
| Figure 21 - SLD of 11 kV Plant site road feeder..... | 80 |
| Figure 22 - SLD of 11 kV ADE feeder..... | 82 |
| Figure 23 - SLD of 11 kV Shaktinagar (Jagda) feeder..... | 84 |
| Figure 24 - SLD of 11 kV PH road feeder..... | 85 |

Verification certificate

CERTIFICATE ISSUED BY CERTIFIED ENERGY AUDITOR

This is to certify that M/s Feedback Infra Private Limited has completed the third-party independent verification of AT&C losses at Rourkela smart city project area for the period FY 17-18 and FY 18-19 (till December). Results of the verification are as follows:-

| Parameter | UoM | FY 2017-18 | FY 2018-19 |
|-----------------------|----------|------------|------------|
| Input Energy | LU | 3,199.09 | 2,964.18 |
| Billed Energy | LU | 2,320.12 | 2,396.70 |
| Billed Amount | INR Lacs | 12,109.35 | 13,304.66 |
| Collected Amount | INR Lacs | 11,610.67 | 12,439.40 |
| Billing Efficiency | % | 72.52% | 80.86 % |
| Collection Efficiency | % | 95.88 % | 93.50 % |
| AT&C loss | % | 30.46% | 24.40 % |

The methodology and results have been verified by undersigned certified energy auditor.

Certified by –



Shailesh Jagannath Kalrao
 (Vice President)
 Feedback Energy Distribution Company (FEDCO)
 Certified Energy Auditor

Executive Summary

Rourkela circle consists of three main divisions from which 11 kV feeders are currently catering to the smart city area under Rourkela Municipal Corporation (RMC). These divisions are – Rourkela Electrical Division (RED), Rourkela Sadar Electrical Division (RSED) and Rajgangpur Electrical Division (RJP). RJP provides only 2 nos. 11 kV feeders catering to Rourkela Smart city area.

This report outlines the process and verification results for baseline parameters such as AT&C loss, technical loss, transformer failure, system reliability and power quality. Data for the study has been collected for the period FY 2017-18 and FY 2018-19 from MRT division and commercial sections of all three divisions of Rourkela circle. Summary of findings regarding AT&C loss study are as follows:

| Parameter | UoM | FY 2017-18 | FY 2018-19 |
|-----------------------|----------|------------|------------|
| Input Energy | LU | 3,199.09 | 2,964.18 |
| Billed Energy | LU | 2,320.12 | 2,396.70 |
| Billed Amount | INR Lacs | 12,109.35 | 13,304.66 |
| Collected Amount | INR Lacs | 11,610.67 | 12,439.40 |
| Billing Efficiency | % | 72.52% | 80.86 % |
| Collection Efficiency | % | 95.88 % | 93.50 % |
| AT&C loss | % | 30.46% | 24.40 % |

Technical loss at 33 kV system is 2.45% and technical loss at 11 kV system (sample feeders) is 7.49%. Voltage at 33 kV and 11 kV level is within permissible limits whereas power factor and harmonics are also within permissible limits. Transformer failure stands at 2.06% only (excluding HDVS transformers)

Background of the study

Need of Smart Grid leading to Smart City

1. Energy needs of the country are growing at a very rapid pace. In order to meet increasing energy demand, amidst growing environmental concerns as well as energy security issues, we need to increase efficiency in all value chain viz. generation, transmission & distribution. More importantly, efficiency needs to be increased to a point where we shall actually be using less energy to power more establishment/ businesses.
2. Further, to be sustainable, we must be able to produce the amount of energy we need, without much impact on environment through renewable and other non- conventional resources. Consumer aspiration on quality supply, as well as operation in open electricity market regime, integration of renewable energy sources which are intermittent and variable in nature, are also posing new challenges which needs to be addressed. Smart Grid offers a solution towards above challenges. Smart Grid is a confluence of Information, Communication, Electrical/ Digital technologies, integrating all users to efficiently balance demand and supply over an increasing complex network.
3. Cities occupy 4% or less of the world's terrestrial surface, yet they are home to almost half the global population, consume close to three-quarters of the world's natural resources, and generate three-quarters of its pollution and wastes. The United Nations estimates that virtually all net global population and economic growth over the next 30 years will occur in cities, leading to a doubling of current populations. India is also not untouched with above phenomenon. Our cities are becoming more populated continuously as people are migrating from rural areas towards urban areas for more facilities, better life, education and employment.
4. India is urbanizing at an unprecedented rate so much that estimates suggest nearly 600 million Indians will be living in cities by 2030, up from 290 million as reported in the 2001 census. Increasing urban population and unprecedented load on aged and insufficient infrastructure in our cities has forced many challenges for fulfilling basic facilities like home, energy, employment, health, mobility etc. In addition, infrastructure to supply commodities like electricity, water, gas is becoming insufficient to cater such an inflow of population. Improved living standard of people is resulting in higher consumer aspirations and affordability.
5. Therefore, there is a need for development of Smart Grid leading to smart cities, to provide quality life for its citizens for inclusive growth, generate employment as well as reduce pressure of infrastructure requirement on other large cities. Strengths of Smart Grid technologies can transform cities to smart cities which shall facilitate in increasing human productivity, realization of inherent urban potential and lesser use of natural resources per person, information access & processing to improve citizen services etc.

Smart Grid Implementation will bring the following advantages:

- a) Accurate and well-timed Meter Reading;
- b) Commercial Loss Reduction;
- c) Remote connection disconnection of consumer load;
- d) Accurate tamper alert;
- e) Notification of sanctioned load violation at consumer level as well as DT overloading;
- f) Effective Outage Management System linked with Sub Station SCADA and Ring Fencing to minimize losses during outage;
- g) Time-based pricing (Time-of-Use Tariff); and
- h) Peak Load Management to maximize available energy

Objectives of the Smart Grid Project

Following objectives have been outlined for development of Smart Grid in Rourkela Smart City

1. Reduction of AT&C Loss.
2. Automate Grid Operations and perform an accurate DT wise Energy Audit.
3. Increase in billed energy.
4. Empowerment of consumers to participate in the energy management.
5. Improvement in reliability by reduction in outage rate and duration.
6. Improved administration decision making through GIS tools.
7. Increase in customer satisfaction and consumer awareness.
8. Proposed Smart Grid technologies, would facilitate efficient, accurate & effective online recording & monitoring of the energy exchanges in distribution system to reduce AT&C losses and operational errors viz. reading error, bias error, typographical errors etc. caused by involvement of human element.
9. Implementing technologies that would enhance quality of power at doorstep of consumers and would help in proper monitoring of assets for extended life.
10. Efficient system operation by better load management.
11. Enable high level of customer satisfaction and increased awareness.
12. Demand Side Management to ensure maximization of available power

Rourkela Smart Grid Leading to Smart City

Rourkela is one of Odisha's five major cities and is one of the largest urban centers located in Chota Nagpur Plateau is an important industrialized city of the region. The region has a rich and long history of indigenous settlement (Tribes like Oraons, Mundas, Kharias, Bhuiyans and Bhumijis). It is also one of the two proposed smart cities from the State of Odisha; selected by the Gol and is the Steel City of Odisha. It has an area of 53.29 km² and its demography provides a Railway gateway for access to Eastern Part of India to Southern Part of India and Western Part of India. The population of Rourkela is over 3.09 lakhs and power consumers are over 81,000 nos. Consumers in Rourkela get electricity from Western Electricity Supply Company of Odisha (WESCO), one of the distribution utilities catering to Western part of Odisha with headquarters at Burla.

WESCO is the power distribution utility distributing electricity to the consumers of western part of Odisha covering 9 revenue districts namely Sambalpur, Bargarh, Jharsuda, Deogarh, Sundargarh, Subarnapur, Bolangir, Kalahandi and Nuapada etc. For smooth functioning of utility, activities is divided into 5 circles comprising different revenue districts.

- a) Sundargarh District- Rourkela Circle

- b) Jharsuguda & Sambalpur District- Sambalpur Circle
- c) Bargarh District- Bargarh Circle
- d) Subarnapur & Bolangir District- Bolangir Circle
- e) Kalahandi & Nuapada District- Kalahandi Circle

Rourkela is divided into mainly 2 urban centers – Rourkela Municipal Corporation (RMC) with an area of 53.3 Sq Kms and the Rourkela Steel Township (RST) with an area of approximately 54 Sq Kms. As per census of 2011, the population of RMC and RST is around 3.09 Lacs and 2.1 Lacs respectively. The current proposal is for development of Smart Grid in RMC area. Known as the Steel City, with the presence of SAIL's first Integrated Steel Plant; Rourkela Industrial Area further has 43 Sponge Iron Plants, 3 cement industries and around 350 MSMEs'. However for implementation of Smart Grid, the following have been excluded:

- a) Area of Rourkela Steel Plant and its residential areas
- b) Area of Railway and its residential colony
- c) Area of National Institute of Technology (NIT) and, its residential colony

Odisha Power Transmission Corporation Ltd (OPTCL) and WESCO have appointed PFC Consulting Ltd (PFCCCL) for undertaking various activities for development and implementation of smart grid in Rourkela city.

PFCCCL has engaged Feedback Infra Pvt. Ltd. for study and evaluation of baseline KPIs for implementation of Smart Grid in Rourkela. The baseline KPIs covered under the project are as follows –




Figure 1 - List of Baseline KPIs covered under the project

Salient features of the distribution network of the smart city area are as follows –

| Sl. No | Particulars | UoM | Value |
|--------|---|---------|------------|
| 1 | Area covered under smart city | Sq. km. | 53.29 |
| 2 | No. of division offices | Nos. | 3 |
| 3 | No. of sub-division offices | Nos. | 7 |
| 4 | Population covered (as per 2011 census) | Nos. | 3.09 Lakhs |
| 5 | Total consumers (approx.) | Nos. | 86,768 |
| 6 | No. of 33 kV feeders (Full & Partially feeding) | Nos. | 10 |
| 7 | No. of 11 kV feeders | Nos. | 42 |
| 8 | Length of 33 kV lines | Ckt km. | 79.01 |
| 9 | Length of 11 kV lines | Ckt km. | 236.23 |
| 10 | Length of LT lines | Ckt km. | 377.81 |
| 11 | No. of 33 / 11 kV substations | Nos. | 18 |
| 12 | No. of 33 / 11 kV power transformers | Nos. | 38 |
| 13 | Capacity of 33 / 11 kV power transformers | MVA | 250.85 |
| 14 | No. of 33 / 0.4 kV distribution transformers | Nos. | 13 |
| 15 | Capacity of 33 / 0.4 kV distribution transformers | MVA | 1.7 |
| 16 | No. of 11 / 0.4 kV distribution transformers | Nos. | 1194 |
| 17 | Capacity of 11 / 0.4 kV distribution transformers | MVA | 167.36 |

Table 1 - Salient features of the distribution network of the smart city area

Category-wise consumer details under smart city area are as follows –

| Sl. No. | Category of consumers | RED | RSED | RJP | Total |
|--------------|-----------------------|---------------|---------------|--------------|---------------|
| 1 | Domestic | 43,676 | 27,179 | 3,411 | 74,266 |
| 2 | Commercial | 7,892 | 3,200 | 811 | 11,903 |
| 3 | PHD | 19 | 19 | 3 | 41 |
| 4 | Street Light | 8 | 1 | 6 | 15 |
| 5 | Small Industry | 147 | 93 | 83 | 323 |
| 6 | Medium Industry | 19 | 75 | 65 | 159 |
| 7 | HT Industry | 23 | 29 | 9 | 61 |
| Total | | 51,784 | 30,596 | 4,388 | 86,768 |

Table 2 - Category-wise consumer details under smart city area

Concept of AT&C losses

AT&C losses provide a realistic picture of energy & revenue loss situation. These losses comprise of two elements-

1. **Technical loss** - The technical losses primarily take place due to the following factors:-
 - a) Transformation Losses (at various transformation levels)

High I²R losses on distribution lines due to inherent resistance and poor power factor in the electrical network. The level of technical losses varies with type of conductors used, transformation capacity of transformers and reactive loads among other factors. There are number of software available in market through which losses can be computed. The essential requirements for calculating technical loss on power distribution network of any project areas are –

- a) 33 kV and below HT network Line Diagrams
 - b) Line Diagrams for each of distribution transformers and LT circuits up to poles/feeder pillars
 - c) Voltage levels, Power factor and Current loading on HT/LT network & network equipment
 - d) Line lengths, cross section & nature of material, network equipment's load curve etc.
2. **Commercial loss** - Any illegal consumption of electrical energy, which is not correctly metered, billed and revenue collected, causes commercial losses to the utilities. The commercial losses are primarily attributable to discrepancies in –

- a. **Meter reading** - Commercial losses occur due to discrepancy in meter reading. Meter reading problems are manifested in form of zero consumption in meter reading books which may be due to premises found locked, untraceable consumers, stopped/defective meters, temporarily disconnected consumers continuing in billing solution etc.

Further, coffee shop reading, collusion with consumers is also source of commercial losses to utilities which are primarily due to suppressed meter reading.

- b. **Metering** - Most of utilities across India are using either electro-mechanical or electronic meters for consumer metering. Commercial losses through metering can be in form of meter tampering in various forms, bypassing of meters, usage of magnets to slow down the meters, tampering of PT circuits, CT/PT ratios (in case of HT meters) etc.
- c. **Theft by direct hooking** - This is most common and visible form of commercial losses in which people tend to tap LT lines to indulge in theft through direct hooking.
- d. **Collection efficiency** - Typically in a billing cycle, a distribution utility issues bills against metered energy and assessed (generally in case of agricultural loads and temporary connections) energy. However, in most of instances utility is not able to collect the complete amount billed by it. The ratio of amount collected to total amount billed is termed as collection efficiency. Needless to say that low collection efficiency implies higher commercial losses.

The revenue collected shall exclude the arrears .However in case figures of arrears not available separately; there is possibility to getting collection efficiency figures of more than 100%. In such cases

efficiency shall be restricted to 100% and shall be used for computation of AT&C losses. The amount attributing collection efficiency higher than 100% shall be treated as collection against arrears.

Methodology of verification

PFC has issued a guideline in September 2009 with regard to methodology for establishing baseline AT&C losses. This methodology underlines the procedure for establishing baseline losses for a project area. Although PFC prescribes the verification of AT&C loss by taking data for 3 billing cycles. The same was reiterated in given scope of work. However, upon consultation, it was suggested that data for FY 2017-18 and FY 2018-19 (Q1 to Q3) shall be collated and analyzed in order to account for seasonal variations.



Figure 2 - Methodology for verification

Field interviews

Information regarding network – such as Single Line Diagrams (SLDs), input energy sheets, billing database etc. has been collected from the office of Superintending Engineer and all three division offices which are covered under the area of Smart city project. Interviews conducted during field visit are as follows:

| Sl. No. | Officer Name | Designation | Circle / Division | Data / Information |
|---------|-------------------|---------------|-------------------|--|
| 1 | Mr. A. N. Meher | SE (Rourkela) | Rourkela | Overview of operations, network etc. |
| 2 | Mr. J. C. Patra | EE (RED) | RED | Network details of feeders in RED division |
| 3 | Mr. B.K. Singh | EE (RSED) | RSED | Network details of feeders in RSED |
| 4 | Mr. P.K. Sahoo | EE (RJP) | RJP | Network details of feeders in RJP division |
| 5 | Mr. P. K. Sahu | DFM | RED | LT Billing database of RED division |
| 6 | Mr. Biswajit Dash | DFM | RSED | LT Billing database of RSED division |
| 7 | Mr. J. P. Lenka | DFM | RJP | LT Billing database of RJP division |
| 8 | Mr. Arvind Sahu | EE | MRT | TTB / Metering of 11 kV feeders |
| 9 | Mrs. Anamika | AE | MRT | Input energy, HT billing data |

Table 3 - List of officials visited

Methodology of sampling

Wherever possible, 100 % samples have been taken. However, due to lack of appropriate data and paucity of time, certain samples have been taken for the dipstick study as mutually agreed with WESCO / OPTCL. Methodology used for sampling is given as follows –

| KPI / Parameter | Sample methodology |
|------------------------------------|---|
| AT&C loss | 100 % feeders covering 33 kV and 11 kV level |
| Technical loss of 33 kV lines | 100% 33 kV feeders |
| Technical loss of 11 kV lines | 8 Nos. of 11 kV feeders as mutually agreed |
| T&D loss of LT network | 10 Nos. of DTs as mutually agreed |
| SAIFI, SAIDI, CAIDI | 100% 11 kV feeders with available data |
| Voltage & PF Profile | 100% 11 kV feeders with available data |
| Total Harmonic Distortion | 100% 11 kV feeders with testing facility |
| Transformer Failure | 100% transformer failure covering all non-HVDS transformers |
| Consumer meter reading and billing | 500 consumers covering all categories and feeders |

Table 4 - Methodology used for sampling

Ring fencing & input points

According to PFC methodology for calculation of AT&C losses, "... utility can do ring fencing of towns through installation of import/export meters at project area boundaries. There can be 11 kV feeders feeding within and outside project area. The utility may install import/export meters at town boundaries and account for total energy supplied beyond town boundaries through them. While computing energy consumption of town, this energy may be subtracted from total energy consumption arrived from meter reading." Therefore, the electrical network of Rourkela has been studied in order to determine import and export points for Smart City area.

The entire city can be divided into three main zones namely –

- a. Rourkela Municipal Corporation area (RMC area)
- b. Rourkela Steel Plant Area (RSP area)
- c. NIT Area

Out of these three areas, RMC area shall only be covered under the Smart city project. Therefore, feeders at 33 kV and 11 kV level providing power within RMC area have been evaluated for the purpose of Baseline study. Methodology of determining the ring fencing is discussed in the following section.

Determination of ring fencing

There are 2 nos. of 132 / 33 kV Grid Sub-Stations (GSS) feeding electricity to Rourkela Smart City project area (RMC area as specified above). There are 10 nos. of 33 kV feeders emanating from these 132 / 33 kV GSS which partially or fully provide power within the Smart city area. Out of these, 6 nos. of 33kV feeders are fully catering to smart city area, whereas 4 nos. partially cater to smart city area.

It may be noted that 33 kV and 11 kV network has undergone changes from FY 17-18 to FY 18-19. Current network configuration of FY 18-19 is given as follows –




Figure 3 - 33 kV network configuration for FY 18-19

Key maps of Rourkela Smart city

Key map of the electrical network of Rourkela Smart city area has been provided by WESCO. This map shows the location of 132 / 33 kV GSS, 33 / 11 kV substations as well as interconnecting 33 kV lines. The key map may be broken down into 5 parts for easy reference. The maps are enclosed for reference




Figure 4 - Key map of smart city area




Figure 5 - Kay map of part 1




Figure 6 - Key map of Part 2




Figure 7 - Key map of Part 3




Figure 9 - Key map of Part 4A

AT&C Loss verification (FY 2017-18)

AT&C loss has been verified for all input points (33 kV and 11 kV) by the following methodology:

Step 1: Individual input of 33 kV and 11 kV feeders have been derived from feeder meter reading by the following formula:

Input Energy (Feeder A) = (Meter reading on 1st April 2018 – Meter reading on 1st April 2017) x Multiplying factor

Step 2: For each division, LT billing data is available as a database file for each month. This billing data consists of billed units, billed amount and collection for each consumer every month. As consumers are tagged with 11 kV feeders, we can derive 11 kV feeder-wise billed units, billed amount and collection from the database. Summation of billed units for connected 11 kV feeders will give the LT units billed for the 33 kV feeder. HT billing data is available as a database file for all HT consumers. A consumer list pertaining to smart city area has been shared by MRT division. This has been followed in deriving billing and collection for HT consumers. With these data, the billing efficiency of the 33 kV feeder can be derived as per the following formula:

Billing Efficiency (Feeder A) = (Billed energy of 33 kV consumers + Billed energy of 11 kV consumers + Billed energy of LT consumers of 11 kV feeders from connected substations) x 100 / Input Energy (Feeder A)

Step 3: Collection Efficiency can be determined as follows:

Collection Efficiency (Feeder A) = (Amount Collected from 33 kV consumers + Amount Collected from 11 kV consumers + Amount Collected from LT consumers of 11 kV feeders from connected substations) x 100 / (33 kV consumers billed amount + 11 kV consumers billed amount + LT consumer billed amount)

Step 4: AT & C for 33 kV feeder –

AT&C loss = 1 – (Billing efficiency x Collection efficiency) %


33 kV Input point feeder-wise losses

33 kV Industrial estate & 33 kV pilot project feeders

The input energy recorded for 33 kV Industrial Estate & 33 kV Pilot Project feeders can be summed up and compared with 11 kV feeders emanating from 33/11 kV Industrial Estate & Pilot Project substations in order to determine loss on 33 kV line and power transformer loss.

It is to be noted that AT&C calculation is done for the two feeders as a whole due to regular switchovers for load sharing.

| Feeder Name | Reading on 1 st April 2017 | Reading on 1 st April 2018 | Multiplying Factor (MF) | Input Energy (LU) |
|--|---------------------------------------|---------------------------------------|-------------------------|-------------------|
| 33 kV Industrial Estate | 71,04,601 | 75,20,804 | 60 | 249.73 |
| 33 kV Pilot Project feeder | 14,29,325 | 15,51,167 | 60 | 45.55 |
| Total input energy for 33 kV Industrial Estate & 33 kV Pilot Project feeder | | | | 295.28 |



Billed units of all 11 kV feeders can be summed up as per the list of feeder codes¹. Billed units for 11 kV feeders are added from database files and the results are collated below –

¹ List of 11 kV feeders with feeder codes provided by WESCO – Annexure 1

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|---|-----------------------|-----------------------------|--------------------------|
| 11 kV Pilot Project (Town) | 2.87 | 1.34 | 4.23 |
| 11 kV Industrial Estate feeder | 105.09 | 5.71 | 110.8 |
| 11 kV Town feeder | 54.34 | 13.64 | 67.98 |
| Total energy billed for connected consumers of 11 kV feeders | | | 182.99 |
| Billed energy for 33 kV consumer M/s Utkal Flour Mills | | | 19.03 |
| Total billed energy 33 kV consumer + 11 kV feeders | | | 202.02 |
| Total input energy for 33 kV Industrial Estate & 33 kV Pilot Project feeder | | | 295.28 |
| Billing efficiency (%) | | | 68.42% |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Pilot Project (Town) | 21.11 | 6.59 | 20.82 | 6.59 |
| 11 kV Industrial Estate feeder | 521.49 | 42.63 | 477.17 | 42.63 |
| 11 kV Town feeder | 330.13 | 93.37 | 419.26 | 93.37 |
| 33 kV Utkal Flour Mill | - | 116.93 | - | 116.93 |
| Total | | 1132.25 | | 1176.77 |
| Collection efficiency (%) | | | | 103.92 % |

Therefore AT&C loss for 33 kV Industrial Estate & 33 kV Pilot Project feeders can be calculated as follows:


| Parameter | Value |
|---|----------------|
| Billing efficiency (%) | 68.42 |
| Collection efficiency (%) (Capped at 100 %) | 100.00 |
| AT&C Loss | 31.58 % |

33 kV old IDC feeder

The input energy recorded for 33 kV Old IDC feeder can be summed up and compared with 11 kV feeders emanating from 33/11 kV Panposh substation in order to determine loss on 33 kV line and power transformer loss.

The Input energy for 33kV IDC feeder is calculated by adding up consumptions as per the load survey data available with WESCO M.R.T division Rourkela

| Feeder Name | Consumption for the month of April 2017 | Cumulative consumption up to the month of April 2018 | Multiplying Factor (MF) | Input Energy (LU) |
|--|---|--|-------------------------|-------------------|
| 33 kV Old IDC feeder | 45.97 | 404.74 | 120 | 450.72 |
| Total input energy for 33 kV Old IDC feeder | | | | 450.72 |



Billed units of all 11 kV feeders can be summed up as per the list of feeder codes². Billed units for 11 kV feeders are added from database files and the results are collated below –

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--|-----------------------|-----------------------------|--------------------------|
| 11 kV PHD feeder | 0.24 | 13.52 | 13.76 |
| 11 kV Raw Water feeder | 23.87 | 35.72 | 59.59 |
| 11 kV College feeder | 90.35 | 27.85 | 118.20 |
| 11 kV Town feeder | 150.61 | - | 150.61 |
| 11 kV RGH feeder | - | - | - |
| Total energy billed for connected consumers of 11 kV feeders | | | 342.16 |
| Billed energy for 33 kV consumer Project Manager PMU | | | 30.36 |
| Billed energy for 33/0.4 kV Balughat (AGLX) | | | 9.31 |
| Total billed energy 33 kV consumer + 11 kV feeders | | | 381.83 |
| Total input energy for 33 kV Old IDC feeder | | | 450.72 |
| Billing efficiency (%) | | | 84.72 % |

² List of 11 kV feeders with feeder codes provided by WESCO – Annexure 1

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV PHD feeder | 1.33 | 70.65 | 1.84 | 70.65 |
| 11 kV Raw Water feeder | 135.06 | 219.96 | 118.69 | 219.96 |
| 11 kV College feeder | 565.87 | 185.33 | 538.94 | 185.33 |
| 11 kV Town feeder | 901.28 | - | 852.31 | - |
| 11 kV RGH feeder | - | - | - | - |
| 33 kV Project Manager PMU | - | 180.591 | - | 180.591 |
| 33/0.4 kV Balughat (AGLX) | 52.57 | - | 39.99 | - |
| Total | | 2312.64 | | 2208.30 |
| Collection efficiency (%) | | | | 95.49% |


Therefore AT&C loss for 33 kV Old IDC feeder can be calculated as follows:

| Parameter | Value |
|---------------------------|----------------|
| Billing efficiency (%) | 84.73 |
| Collection efficiency (%) | 95.49 |
| AT&C Loss | 19.11 % |

33 kV Power House (Town – 2) feeder

The input energy recorded for 33 kV Town - 2 feeder can be summed up and compared with 11 kV feeders emanating from 33/11 kV Power house road substation in order to determine loss on 33 kV line and power transformer loss.

| Feeder Name | Reading as on 1 st April 2017 | Reading as on 1 st April 2018 | Multiplying Factor (MF) | Input Energy (LU) |
|---|--|--|-------------------------|-------------------|
| 33 kV Town-2 Feeder | 90,30,284 | 95,94,298 | 120 | 676.81 |
| Total input energy for 33 kV Town - 2 feeder | | | | 676.81 |



Billed units of all 11 kV feeders can be summed up as per the list of feeder codes³. Billed units for 11 kV feeders are added from database files and the results are collated below –

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--|-----------------------|-----------------------------|--------------------------|
| 11 kV Udit Nagar feeder | 133.49 | 22.69 | 156.18 |
| 11 kV Main Road feeder | 121.73 | 75.01 | 196.74 |
| 11 kV Power house road | 58.85 | 0 | 58.85 |
| 11 kV Plant Site feeder | 106.59 | 2.62 | 109.21 |
| Total energy billed for connected consumers of 11 kV feeders | | | 520.98 |
| Total input energy for 33 kV Town - 2 feeder | | | 676.81 |
| Billing efficiency (%) | | | 76.98% |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Udit Nagar feeder | 718.36 | 137.02 | 734.93 | 137.02 |
| 11 kV Main Road feeder | 641.13 | 486.05 | 688.66 | 486.05 |
| 11 kV Power house road | 274.13 | 0 | 283.71 | 0 |
| 11 kV Plant Site feeder | 516.54 | 24.1 | 466.78 | 24.1 |
| Total | 2797.33 | | 2821.25 | |
| Collection efficiency (%) | | | | 100.86% |

Therefore AT&C loss for 33 kV Town - 2 feeder can be calculated as follows:

³ List of 11 kV feeders with feeder codes provided by WESCO – Annexure 1



| Parameter | Value |
|---|---------------|
| Billing efficiency (%) | 76.98 |
| Collection efficiency (%) (Capped at 100 %) | 100.00 |
| AT&C Loss | 23.02% |

It may be noted that according to PFC guidelines Collection efficiency shall be considered not more than 100% while computing AT&C losses.

33 kV Basanti feeder

The input energy recorded for 33 kV Basanti feeder can be summed up and compared with 11 kV feeders emanating from 33/11 kV Basanti substation in order to determine loss on 33 kV line and power transformer loss.

| Feeder Name | Reading on 1 st April 2017 | Reading on 1 st April 2018 | Multiplying Factor (MF) | Input Energy (LU) |
|--|---------------------------------------|---------------------------------------|-------------------------|-------------------|
| 33 kV Basanti feeder | 7,17,909 | 15,01,286 | 60 | 470.03 |
| Total input energy for 33 kV Basanti feeder | | | | 470.03 |



Billed units of all 11 kV feeders can be summed up as per the list of feeder codes. Billed units for 11 kV feeders are added from database files and the results are collated below –

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--|-----------------------|-----------------------------|--------------------------|
| 11 kV DAV feeder | 117 | 0 | 117 |
| 11 kV PHD feeder | 48.28 | 1.75 | 50.03 |
| 11 kV MS Palli feeder | 117.62 | 2.05 | 119.67 |
| Total energy billed for connected consumers of 11 kV feeders | | | 286.70 |
| Total input energy for 33 kV Basanti & Town 1 feeder | | | 470.03 |
| Billing efficiency (%) | | | 61.00% |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV DAV feeder | 492.67 | - | 477.42 | - |
| 11 kV PHD feeder | 231.16 | 12.19 | 235.53 | 12.19 |
| 11 kV MS Palli feeder | 507.89 | 14.89 | 254.25 | 14.89 |
| Total | | 1258.80 | | 994.28 |
| Collection efficiency (%) | | | | 78.98% |


Therefore AT&C loss for 33 kV Basanti & Town – 1 feeder can be calculated as follows:

| Parameter | Value |
|---------------------------|---------------|
| Billing efficiency (%) | 61.00 |
| Collection efficiency (%) | 78.98 |
| AT&C Loss | 51.82% |

33 kV Chhend-Koelnagar feeder

The input energy recorded for 33 kV Chhend-Koelnagar feeder can be summed up and compared with 11 kV feeders emanating from 33/11 kV Chhend and 33/11 kV Koelnagar substations in order to determine loss on 33 kV line and power transformer loss. The Chhend Loelnagar feeder is also connected to 33/11 kV Kalingavihar Substation. So the effective input for the smart city area

| Feeder Name | Reading on 1 st April 2017 | Reading on 1 st April 2018 | Multiplying Factor (MF) | Input Energy (LU) |
|---|---------------------------------------|---------------------------------------|-------------------------|-------------------|
| 33 kV Chhend-Koelnagar | 180,90,580 | 187,21,100 | 120 | 756.62 |
| Total input energy for 33 kV Chhend-Koelnagar feeder | | | | 756.62 |



Billed units of all 11 kV feeders can be summed up as per the list of feeder codes. Billed units for 11 kV feeders are added from database files and the results are collated below –

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--|-----------------------|-----------------------------|--------------------------|
| 11 kV Jhirpani feeder | 48.10 | 5.77 | 53.87 |
| 11 kV BC Block feeder | 51.15 | - | 51.15 |
| 11 kV ADE Block feeder | 80.37 | - | 80.37 |
| 11 kV Hamirpur feeder | 36.65 | - | 36.65 |
| 11 kV Self Finance feeder | 54.84 | 1.49 | 56.33 |
| 11 kV Panposh feeder | 52.33 | 3.02 | 55.35 |
| 11 kV RDA feeder | 35.39 | 2.50 | 37.89 |
| 11 kV Chhend 1 st Phase | 73.08 | | 73.08 |
| 11 kV Kalinga Vihar | 61.05 | | 61.05 |
| 11 kV Luhakera | 23.21 | 5.64 | 28.84 |
| Total energy billed for connected consumers of 11 kV feeders | | | 534.59 |
| Total input energy for 33 kV Chhend-Koelnagar feeder | | | 756.62 |
| Billing efficiency (%) | | | 70.65 % |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Jhirpani feeder | 215.01 | 37.58 | 190.95 | 37.58 |
| 11 kV BC Block feeder | 228.81 | - | 248.89 | - |
| 11 kV ADE Block feeder | 383.12 | - | 415.99 | - |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|------------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Hamirpur feeder | 155.25 | - | 153.65 | - |
| 11 kV Self Finance feeder | 280.24 | 13.35 | 262.45 | 13.35 |
| 11 kV Panposh feeder | 271.62 | 23.24 | 218.99 | 23.24 |
| 11 kV RDA feeder | 170.14 | 13.35 | 154.94 | 13.35 |
| 11 kV Chhend 1 st Phase | 368.13 | - | 336.46 | - |
| 11 kV Kalinga Vihar | 305.08 | - | 278.53 | - |
| 11 kV Luhakera | 119.66 | 24.50 | 60.90 | 24.50 |
| Total | | 2609.08 | | 2433.77 |
| Collection efficiency (%) | | | | 93.28 % |

Therefore AT&C loss for 33 kV Chhend-Koelnagar feeder can be calculated as follows:

| Parameter | Value |
|---------------------------|----------------|
| Billing efficiency (%) | 70.65 |
| Collection efficiency (%) | 93.28 |
| AT&C Loss | 34.09 % |

11 kV Input point feeder-wise losses

11 kV Modern India - 1 feeder

11 kV Modern India – 1 feeder emanates from 33/11 kV Lathikata substation which in turn is supplied power through 33 kV Lathikata feeder from 132/33 kV Rourkela GSS. While other feeders from 33/11 kV Lathikata substation cater to areas outside smart city, 11 kV Modern India – 1 (partially) caters to Rourkela Smart city area. Input energy of the feeder is calculated as follows:

The total transformation capacity installed on the feeder is 8000kVA, out of that around 800kVA of transformation capacity falls under the smart city area. Therefore the input billing and collection is proportioned to be 10% of the total figures of the feeder as whole.

| Feeder Name | Input Energy (LU) |
|-------------------------------|-------------------|
| 11 kV Modern India - I feeder | 11.47 |

Billed units for the feeder can be derived by adding up LT billed energy from LT billing database provided by DFMs and HT billed energy from HT billing database provided by MRT division.

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--|-----------------------|-----------------------------|--------------------------|
| 11 kV Modern India - I (AIAA) | 9.08 | - | 9.08 |
| Total input energy for 11 kV Modern India - 1 feeder | | | 11.47 |
| Billing efficiency (%) | | | 79.00 % |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Modern India - I (AIAA) | 39.50 | - | 41.17 | - |
| Total | 39.50 | | 41.17 | |
| Collection efficiency (%) | | | | 104.22 % |

Therefore AT&C loss for 11 kV Modern India – 1 feeder can be calculated as follows:

| Parameter | Value |
|--|----------------|
| Billing efficiency (%) | 79.00 % |
| Collection efficiency (%) (Capped at 100%) | 100.00 % |
| AT&C Loss | 21.00 % |

11 kV Ved Vyas feeder

11 kV Vedvyas feeder emanates from 33/11 kV Vedvyas substation which in turn is supplied power through 33 kV Vedvyas feeder from 132/33 kV Chhend GSS. While other feeders from 33/11 kV Vedvyas substation cater to areas outside smart city, 11 kV Vedvyas and 11 kV Gopapalli feeders cater to Rourkela Smart city area. Input energy of the feeder is calculated as follows:

| Feeder Name | Reading on 1 st April 2017 | Reading on 1 st April 2018 | Multiplying Factor (MF) | Input Energy (LU) |
|--|---------------------------------------|---------------------------------------|-------------------------|-------------------|
| 11 kV Vedvyas feeder | 5258.61 | 5,867.71 | 20000 | 121.82 |
| Total input energy for 11 kV Vedvyas feeder | | | | 121.82 |

Billed units for the feeder can be derived by adding up LT billed energy from LT billing database provided by DFMs and HT billed energy from HT billing database provided by MRT division.

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|---|-----------------------|-----------------------------|--------------------------|
| 11 kV Vedvyas (BDCC) | 78.21 | 25.87 | 104.08 |
| Total input energy for 11 kV Vedvyas feeder | | | 121.82 |
| Billing efficiency (%) | | | 85.44 % |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Vedvyas (BDCC) | 457.65 | 177.21 | 454.36 | 177.21 |
| Total | | 634.86 | | 631.57 |
| Collection efficiency (%) | | | | 99.48 % |

Therefore AT&C loss for 11 kV Vedvyas feeder can be calculated as follows:

| Parameter | Value |
|---------------------------|----------------|
| Billing efficiency (%) | 85.44 |
| Collection efficiency (%) | 99.48 |
| AT&C Loss | 15.00 % |

11 kV Gopapalli feeder

11 kV Gopapalli feeder emanates from 33/11 kV Vedvyas substation which in turn is supplied power through 33 kV Vedvyas feeder from 132/33 kV Chhend GSS. While other feeders from 33/11 kV Vedvyas substation cater to areas outside smart city, 11 kV Vedvyas and 11 kV Gopapalli feeders caters to Rourkela Smart city area. Input energy of the feeder is calculated as follows:

| Feeder Name | Reading on 1 st April 2017 | Reading on 1 st April 2018 | Multiplying Factor (MF) | Input Energy (LU) |
|--|---------------------------------------|---------------------------------------|-------------------------|-------------------|
| 11 kV Gopapalli feeder | 11,029.88 | 11,340.44 | 20000 | 62.11 |
| Total input energy for 11 kV Gopapalli feeder | | | | 62.11 |

Billed units for the feeder can be derived by adding up LT billed energy from LT billing database provided by DFMs and HT billed energy from HT billing database provided by MRT division.

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|---|-----------------------|-----------------------------|--------------------------|
| 11 kV Gopapalli (BDCB) | 25.77 | 10.51 | 36.28 |
| Total input energy for 11 kV Gopapalli feeder | | | 62.11 |
| Billing efficiency (%) | | | 58.41 % |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Gopapalli (BDCB) | 148.46 | 69.79 | 142.57 | 69.79 |
| Total | | 218.25 | | 212.36 |
| Collection efficiency (%) | | | | 97.30 % |

Therefore AT&C loss for 11 kV Gopapalli feeder can be calculated as follows:

| Parameter | Value |
|---------------------------|----------------|
| Billing efficiency (%) | 58.41 |
| Collection efficiency (%) | 97.30 |
| AT&C Loss | 43.16 % |

11 kV Nayabazar feeder

11 kV Nayabazar feeder emanates from 33/11 kV REC substation which in turn is supplied power through 33 kV NIT feeder from 132/33 kV Chhend GSS. All three feeders from 33/11 kV REC substation cater to areas within smart city. Input energy of 11 kV Nayabazar feeder is calculated as follows:

| Feeder Name | Reading on 1 st April 2017 | Reading on 1 st April 2018 | Multiplying Factor (MF) | Input Energy (LU) |
|--|---------------------------------------|---------------------------------------|-------------------------|-------------------|
| 11 kV Nayabazar feeder | 59,487.23 | 63,169.79 | 4000 | 147.30 |
| Total input energy for 11 kV Nayabazar feeder | | | | 147.30 |

Billed units for the feeder can be derived by adding up LT billed energy from LT billing database provided by DFMs and HT billed energy from HT billing database provided by MRT division.

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|---|-----------------------|-----------------------------|--------------------------|
| 11 kV Nayabazar (AAAA) | 91.91 | 5.3 | 97.21 |
| Total input energy for 11 kV Nayabazar feeder | | | 147.30 |
| Billing efficiency (%) | | | 65.99 % |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Nayabazar (AAAA) | 381.92 | 27.01 | 355.02 | 27.01 |
| Total | | 408.93 | | 382.03 |
| Collection efficiency (%) | | | | 93.42 % |

Therefore AT&C loss for 11 kV Nayabazar feeder can be calculated as follows:

| Parameter | Value |
|---------------------------|----------------|
| Billing efficiency (%) | 65.99 |
| Collection efficiency (%) | 93.42 |
| AT&C Loss | 38.35 % |

11 kV OSAP feeder

11 kV OSAP feeder emanates from 33/11 kV REC substation which in turn is supplied power through 33 kV NIT feeder from 132/33 kV Chhend GSS. All three feeders from 33/11 kV REC substation cater to areas within smart city. Input energy of 11 kV OSAP feeder is calculated as follows:

| Feeder Name | Reading on 1 st April 2017 | Reading on 1 st April 2018 | Multiplying Factor (MF) | Input Energy (LU) |
|---|---------------------------------------|---------------------------------------|-------------------------|-------------------|
| 11 kV OSAP feeder | 29,020.87 | 30,920.86 | 6000 | 113.99 |
| Total input energy for 11 kV OSAP feeder | | | | 113.99 |

Billed units for the feeder can be derived by adding up LT billed energy from LT billing database provided by DFMs and HT billed energy from HT billing database provided by MRT division.

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--|-----------------------|-----------------------------|--------------------------|
| 11 kV OSAP (AAAD) | 69.92 | - | 69.92 |
| Total input energy for 11 kV OSAP feeder | | | 113.99 |
| Billing efficiency (%) | | | 61.33 % |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV OSAP (AAAD) | 320.47 | - | 314.41 | - |
| Collection efficiency (%) | | | | 98.11% |

Therefore AT&C loss for 11 kV OSAP feeder can be calculated as follows:

| Parameter | Value |
|---------------------------|----------------|
| Billing efficiency (%) | 61.33 |
| Collection efficiency (%) | 98.11 |
| AT&C Loss | 39.82 % |

It may be noted that according to the guidelines Collection efficiency shall be considered not more than 100% while computing AT&C losses.

11 kV Shaktinagar feeder

11 kV Shaktinagar feeder emanates from 33/11 kV REC substation which in turn is supplied power through 33 kV NIT feeder from 132/33 kV Chhend GSS. All three feeders from 33/11 kV REC substation cater to areas within smart city. Input energy of 11 kV Shaktinagar feeder is calculated as

| Feeder Name | Reading on 1 st April 2017 | Reading on 1 st April 2018 | Multiplying Factor (MF) | Input Energy (LU) |
|--|---------------------------------------|---------------------------------------|-------------------------|-------------------|
| 11 kV Shaktinagar Feeder | 9759.82 | 15956.4 | 1500 | 92.95 |
| Total input energy for 11 kV Shaktinagar feeder | | | | 92.95 |

Billed units for the feeder can be derived by adding up LT billed energy from LT billing database provided by DFMs and HT billed energy from HT billing database provided by MRT division.

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|---|-----------------------|-----------------------------|--------------------------|
| 11 kV Shaktinagar (AAAB) | 74.35 | 3.08 | 77.43 |
| Total input energy for 11 kV Shaktinagar feeder | | | 92.95 |
| Billing efficiency (%) | | | 83.30% |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Shaktinagr (AAAB) | 354.57 | 22.67 | 372.09 | 22.67 |
| Collection efficiency (%) | | | | 104.60% |

Therefore AT&C loss for 11 kV Shaktinagar feeder can be calculated as follows:

| Parameter | Value |
|--|---------------|
| Billing efficiency (%) | 83.30 |
| Collection efficiency (%) (Capped at 100%) | 100.00 |
| AT&C Loss | 16.70% |

It may be noted that according to the guidelines Collection efficiency shall be considered not more than 100% while computing AT&C losses.

Total Input energy into the smart city area

| Sl. No. | Feeder Name | Input Energy (LU) |
|--|--------------------------------|-------------------|
| 1 | 33 kV Industrial Estate feeder | 249.72 |
| 2 | 33 kV Pilot Project feeder | 45.55 |
| 3 | 33 kV Old IDC feeder | 450.72 |
| 4 | 33 kV Town - 2 feeder | 676.81 |
| 5 | 33 kV Basanti feeder | 470.03 |
| 6 | 33 kV Town-1 feeder | |
| 7 | 33 kV Chhend-Koelnagar feeder | 756.62 |
| 8 | 11 kV Modern India - I feeder | 11.47 |
| 9 | 11 kV Vedvyas feeder | 121.82 |
| 10 | 11 kV Gopapalli feeder | 62.11 |
| 11 | 11 kV Nayabazar feeder | 147.3 |
| 12 | 11 kV OSAP feeder | 113.99 |
| 13 | 11 kV Shaktinagar feeder | 92.95 |
| Total input energy for Rourkela smart city (FY 2017-18) | | 3,199.09 |

Billed energy booked under the smart city area

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--------------------------------|-----------------------|-----------------------------|--------------------------|
| 11 kV Pilot Project (Town) | 2.87 | 1.34 | 4.21 |
| 11 kV Industrial Estate feeder | 105.09 | 5.71 | 110.8 |
| 11 kV Town feeder | 54.34 | 13.64 | 67.98 |
| 11 kV PHD feeder | 0.24 | 13.52 | 13.76 |
| 11 kV Raw Water feeder | 23.87 | 35.72 | 59.59 |
| 11 kV College feeder | 90.35 | 27.85 | 118.2 |
| 11 kV Town feeder | 150.61 | 0 | 150.61 |
| 11 kV RGH feeder | 0 | 0 | 0 |
| 11 kV Udit Nagar feeder | 133.49 | 22.69 | 156.18 |
| 11 kV Main Road feeder | 121.73 | 75.01 | 196.74 |
| 11 kV Power house road | 58.85 | 0 | 58.85 |

| | | | |
|--|---------|--------|---------------|
| 11 kV Plant Site feeder | 106.59 | 2.62 | 109.21 |
| 11 kV DAV feeder | 117 | 0 | 117 |
| 11 kV PHD feeder | 48.28 | 1.75 | 50.03 |
| 11 kV MS Palli feeder | 117.62 | 2.05 | 119.67 |
| 11 kV Jhirpani feeder | 48.1 | 5.77 | 53.87 |
| 11 kV BC Block feeder | 51.15 | 0 | 51.15 |
| 11 kV ADE Block feeder | 80.37 | 0 | 80.37 |
| 11 kV Hamirpur feeder | 36.65 | 0 | 36.65 |
| 11 kV Self Finance feeder | 54.84 | 1.49 | 56.33 |
| 11 kV Panposh feeder | 52.33 | 3.02 | 55.35 |
| 11 kV RDA feeder | 35.39 | 2.5 | 37.89 |
| 11 kV Chhend 1 st Phase | 73.08 | | 73.08 |
| 11 kV Kalinga Vihar | 61.05 | | 61.05 |
| 11 kV Luhakera | 23.21 | 5.64 | 28.85 |
| 11 kV Modern India - I (AIAA) | 9.08 | 0 | 9.08 |
| 11 kV Vedvyas (BDCC) | 78.21 | 25.87 | 104.08 |
| 11 kV Gopapalli (BDCB) | 25.77 | 10.51 | 36.28 |
| 11 kV Nayabazar (AAAA) | 91.91 | 5.3 | 97.21 |
| 11 kV OSAP (AAAD) | 69.92 | 0 | 69.92 |
| 11 kV Shaktinagar (AAAB) | 74.35 | 3.08 | 77.43 |
| Total LT & 11 kV HT | 1996.34 | 265.08 | 2261.42 |
| Total energy billed for connected consumers of 11 kV feeders | | | 2261.42 |
| Billed energy for 33 kV consumers and DT | | | 58.7 |
| Total billed energy 33 kV consumer + 11 kV feeders | | | 2,320.12 |
| Total input energy | | | 3,199.09 |
| Billing efficiency (%) | | | 72.52% |

Billed units for HT consumers

| Sl. No. | Consumer Name | Billed Energy (LU) |
|---------|-----------------------|--------------------|
| 1 | Utkal Flour Mills | 19.03 |
| 2 | Project Manager (PMU) | 30.36 |

| SI. No. | Consumer Name | Billed Energy (LU) |
|---------|--------------------------------|--------------------|
| 3 | 33/0.4 kV Balughat transformer | 9.31 |

Collection booked under the smart city area

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|------------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 33 kV Utkal Flour Mill | 0 | 116.93 | 0 | 116.93 |
| 33 kV Project Manager PMU | 0 | 180.591 | 0 | 180.591 |
| 33/0.4 kV Balughat (AGLX) | 52.57 | 0 | 39.99 | 0 |
| 11 kV Pilot Project (Town) | 21.11 | 6.59 | 20.82 | 6.59 |
| 11 kV Industrial Estate feeder | 521.49 | 42.63 | 477.17 | 42.63 |
| 11 kV Town feeder | 330.13 | 93.37 | 419.26 | 93.37 |
| 11 kV PHD feeder | 1.33 | 70.65 | 1.84 | 70.65 |
| 11 kV Raw Water feeder | 135.06 | 219.96 | 118.69 | 219.96 |
| 11 kV College feeder | 565.87 | 185.33 | 538.94 | 185.33 |
| 11 kV Town feeder | 901.28 | - | 852.31 | - |
| 11 kV RGH feeder | | | | |
| 11 kV DAV feeder | 492.67 | 0 | 477.42 | 0 |
| 11 kV PHD feeder | 231.16 | 12.19 | 235.53 | 12.19 |
| 11 kV MS Palli feeder | 507.89 | 14.89 | 254.25 | 14.89 |
| 11 kV Jhirpani feeder | 215.01 | 37.58 | 190.95 | 37.58 |
| 11 kV BC Block feeder | 228.81 | 0 | 248.89 | 0 |
| 11 kV ADE Block feeder | 383.12 | 0 | 415.99 | 0 |
| 11 kV Hamirpur feeder | 155.25 | 0 | 153.65 | 0 |
| 11 kV Self Finance feeder | 280.24 | 13.35 | 262.45 | 13.35 |
| 11 kV Panposh feeder | 271.62 | 23.24 | 218.99 | 23.24 |
| 11 kV RDA feeder | 170.14 | 13.35 | 154.94 | 13.35 |
| 11 kV Chhend 1 st Phase | 368.13 | 0 | 336.46 | 0 |
| 11 kV Kalinga Vihar | 305.08 | 0 | 278.53 | 0 |
| 11 kV Luhakera | 119.66 | 24.5 | 60.9 | 24.5 |
| 11 kV Udit Nagar feeder | 718.36 | 137.02 | 734.93 | 137.02 |
| 11 kV Main Road feeder | 641.13 | 486.05 | 688.66 | 486.05 |

| | | | | |
|----------------------------------|----------|--------|----------|---------------|
| 11 kV Power house road | 274.13 | 0 | 283.71 | 0 |
| 11 kV Plant Site feeder | 516.54 | 24.1 | 466.78 | 24.1 |
| 11kV Modern India 1 | 39.5 | 0 | 41.17 | 0 |
| 11 kV Vedvyas (BDCC) | 457.65 | 177.21 | 454.36 | 177.21 |
| 11 kV Gopapalli (BDCB) | 148.46 | 69.79 | 142.57 | 69.79 |
| 11 kV Nayabazar (AAAA) | 381.92 | 27.01 | 355.02 | 27.01 |
| 11 kV OSAP (AAAD) | 320.47 | 0 | 314.41 | 0 |
| 11 kV Shaktinagar | 354.57 | 22.67 | 372.09 | 22.67 |
| Total | 12109.35 | | 11610.67 | |
| Collection efficiency (%) | | | | 95.88% |

The total AT&C losses, input feeder wise in Rourkela Smart City area as a whole under WESCO Rourkela circle for FY 2017-18 is tabulated below:

| Sl. No. | Feeder Name | Input Energy (LU) | Billed Energy (LU) | Billed Amount(Lacs) | Collected amount(Lacs) | Billing Efficiency | Collection Efficiency | AT&C |
|--|--------------------------------|-------------------|--------------------|---------------------|------------------------|--------------------|-----------------------|------------|
| | | a | b | c | d | e=b/a | f=d/c | g=1-e*f |
| 1 | 33 kV Industrial Estate feeder | 249.72 | 202.02 | 1132.25 | 1176.77 | 68% | 104% | 32% |
| 2 | 33 kV Pilot Project feeder | 45.55 | | | | | | |
| 3 | 33 kV Old IDC feeder | 450.72 | 381.83 | 2312.64 | 2208.30 | 85% | 95% | 19% |
| 4 | 33 kV Town - 2 feeder | 676.81 | 520.98 | 2797.33 | 2821.25 | 77% | 101% | 23% |
| 5 | 33 kV Basanti feeder | 470.03 | 286.70 | 1258.80 | 994.28 | 61% | 79% | 52% |
| 6 | 33 kV Town-1 feeder | | | | | | | |
| 7 | 33 kV Chhend-Koelnagar feeder | 756.62 | 534.59 | 2609.08 | 2433.77 | 71% | 93% | 34% |
| 8 | 11 kV Modern India - I feeder | 11.47 | 9.08 | 39.50 | 41.17 | 79% | 104% | 21% |
| 9 | 11 kV Vedvyas feeder | 121.82 | 104.08 | 634.86 | 631.57 | 85% | 99% | 15% |
| 10 | 11 kV Gopapalli feeder | 62.11 | 36.28 | 218.25 | 212.36 | 58% | 97% | 43% |
| 11 | 11 kV Nayabazar feeder | 147.3 | 97.21 | 408.93 | 382.03 | 66% | 93% | 38% |
| 12 | 11 kV OSAP feeder | 113.99 | 69.92 | 320.47 | 314.41 | 61% | 98% | 40% |
| 13 | 11 kV Shaktinagar feeder | 92.95 | 77.43 | 377.24 | 394.76 | 83% | 105% | 17% |
| Total for Rourkela smart city area (FY 2017-18) | | 3,199.09 | 2,320.12 | 12,109.35 | 11,610.67 | 73% | 96% | 30% |

AT&C Loss verification (FY 2018-19)

AT&C loss has been verified for all input points (33 kV and 11 kV) by the following methodology:

Step 1: Individual input of 33 kV and 11 kV feeders have been derived from feeder meter reading by the following formula:

Input Energy (Feeder A) = (Meter reading on 1st April 2019 – Meter reading on 1st April 2018) x Multiplying factor

Step 2: For each division, LT billing data is available as a database file for each month. This billing data consists of billed units, billed amount and collection for each consumer every month. As consumers are tagged with 11 kV feeders, we can derive 11 kV feeder-wise billed units, billed amount and collection from the database. Summation of billed units for connected 11 kV feeders will give the LT units billed for the 33 kV feeder. HT billing data is available as a database file for all HT consumers. A consumer list pertaining to smart city area has been shared by MRT division. This has been followed in deriving billing and collection for HT consumers. With these data, the billing efficiency of the 33 kV feeder can be derived as per the following formula:

Billing Efficiency (Feeder A) = (Billed energy of 33 kV consumers + Billed energy of 11 kV consumers + Billed energy of LT consumers of 11 kV feeders from connected substations) x 100 / Input Energy (Feeder A)

Step 3: Collection Efficiency can be determined as follows:

Collection Efficiency (Feeder A) = (Amount Collected from 33 kV consumers + Amount Collected from 11 kV consumers + Amount Collected from LT consumers of 11 kV feeders from connected substations) x 100 / (33 kV consumers billed amount + 11 kV consumers billed amount + LT consumer billed amount)

Step 4: AT & C for 33 kV feeder –

AT&C loss = 1 – (Billing efficiency x Collection efficiency) %


33 kV Input point feeder-wise losses

33 kV Industrial estate & 33 kV pilot project feeders

The input energy recorded for 33 kV Industrial Estate & 33 kV Pilot Project feeders can be summed up and compared with 11 kV feeders emanating from 33/11 kV Industrial Estate & Pilot Project substations in order to determine loss on 33 kV line and power transformer loss.

It is to be noted that AT&C calculation is done for the two feeders as a whole due to regular switchovers for load sharing throughout FY 18-19.

| Feeder Name | Reading on 1 st April 2018 | Reading on 1 st April 2019 | Multiplying Factor (MF) | Input Energy (LU) |
|--|---------------------------------------|---------------------------------------|-------------------------|-------------------|
| 33 kV Industrial Estate | 75,20,804 | 79,00,714 | 60 | 227.95 |
| 33 kV Pilot Project feeder | 15,05,249 | 15,67,666 | 60 | 37.45 |
| Input energy for 33 kV Industrial Estate & 33 kV Pilot Project feeder | | | | 265.40 |



Billed units of all 11 kV feeders can be summed up as per the list of feeder codes⁴. Billed units for 11 kV feeders are added from database files and the results are collated below –

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--------------------------------|-----------------------|-----------------------------|--------------------------|
| 11 kV Pilot Project (Town) | 3.33 | 1.09 | 4.42 |
| 11 kV Industrial Estate feeder | 123.56 | 6.40 | 129.96 |
| 11 kV Town feeder | 38.06 | 15.41 | 53.47 |

⁴ List of 11 kV feeders with feeder codes provided by WESCO – Annexure 1

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|---|-----------------------|-----------------------------|--------------------------|
| Total energy billed for connected consumers of 11 kV feeders | | | 187.86 |
| Billed energy for 33 kV consumer M/s Utkal Flour Mills | | | 18.80 |
| Total billed energy 33 kV consumer + 11 kV feeders | | | 206.66 |
| Total input energy for 33 kV Industrial Estate & 33 kV Pilot Project feeder | | | 265.40 |
| Billing efficiency (%) | | | 77.87 % |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Pilot Project (Town) | 24.60 | 6.59 | 27.09 | 6.59 |
| 11 kV Industrial Estate feeder | 710.36 | 44.22 | 687.54 | 44.22 |
| 11 kV Town feeder | 235.90 | 106.64 | 209.02 | 106.64 |
| 33 kV Utkal Flour Mill | - | 118.92 | - | 118.92 |
| Total | | 1247.23 | | 1200.02 |
| Collection efficiency (%) | | | | 96.21 % |

Therefore AT&C loss for 33 kV Industrial Estate & 33 kV Pilot Project feeders can be calculated as follows:


| Parameter | Value |
|---------------------------|----------------|
| Billing efficiency (%) | 77.87 % |
| Collection efficiency (%) | 96.21 % |
| AT&C Loss | 25.08 % |

33 kV old IDC feeder

The input energy recorded for 33 kV Old IDC feeder can be summed up and compared with 11 kV feeders emanating from 33/11 kV Panposh substation in order to determine loss on 33 kV line and power transformer loss.

The Input energy for 33kV IDC feeder is calculated by adding up consumptions as per the load survey data available with WESCO M.R.T division Rourkela

| Feeder Name | Reading on 1 st April 2018 | Reading on 1 st April 2019 | Multiplying Factor (MF) | Input Energy (LU) |
|--|---------------------------------------|---------------------------------------|-------------------------|-------------------|
| 33 kV Old IDC feeder | 43,05,320 | 46,70,309.00 | 120 | 437.99 |
| Total input energy for 33 kV Old IDC feeder | | | | 437.99 |



Billed units of all 11 kV feeders can be summed up as per the list of feeder codes⁵. Billed units for 11 kV feeders are added from database files and the results are collated below –

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--|-----------------------|-----------------------------|--------------------------|
| 11 kV PHD feeder | 0.42 | 15.37 | 15.79 |
| 11 kV Raw Water feeder | 24.29 | 32.88 | 57.17 |
| 11 kV College feeder | 92.82 | 29.38 | 122.20 |
| 11 kV Town feeder | 161.56 | - | 161.56 |
| 11 kV RGH feeder | - | - | - |
| Total energy billed for connected consumers of 11 kV feeders | | | 356.73 |
| Billed energy for 33 kV consumer Project Manager PMU | | | 33.47 |
| Billed energy for 33/0.4 kV Balughat (AGLX) | | | 8.73 |
| Total billed energy 33 kV consumer + 11 kV feeders | | | 398.92 |
| Total input energy for 33 kV Old IDC feeder | | | 437.99 |
| Billing efficiency (%) | | | 91.08% |

⁵ List of 11 kV feeders with feeder codes provided by WESCO – Annexure 1

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV PHD feeder | 1.99 | 87.19 | 2.24 | 87.19 |
| 11 kV Raw Water feeder | 134.35 | 196.62 | 128.88 | 196.62 |
| 11 kV College feeder | 572.95 | 199.18 | 581.54 | 199.18 |
| 11 kV Town feeder | 959.25 | - | 974.35 | - |
| 11 kV RGH feeder | - | - | - | - |
| 33 kV Project Manager PMU | - | 189.10 | - | 189.10 |
| 33/0.4 kV Balughat (AGLX) | 48.98 | - | 56.63 | - |
| Total | | 2389.61 | | 2415.73 |
| Collection efficiency (%) | | | | 101.09 % |

Therefore AT&C loss for 33 kV Old IDC feeder can be calculated as follows:


| Parameter | Value |
|--|---------------|
| Billing efficiency (%) | 91.08 % |
| Collection efficiency (%) (Capped at 100%) | 100.00 % |
| AT&C Loss | 8.92 % |

33 kV Power House (Town – 2) feeder

The input energy recorded for 33 kV Town - 2 feeder can be summed up and compared with 11 kV feeders emanating from 33/11 kV Power house road substation in order to determine loss on 33 kV line and power transformer loss.

The meter for the said feeder was replaced on December 2018, new readings were available from January 2019. The consumption of December (4167360 units) was calculated based on the readings that MRT department has obtained from Substation log-book.

| Feeder Name | Reading as on 1 st April 2018 | Reading as on 1 st December 2019 | Multiplying Factor (MF) | Input Energy (LU) |
|---|--|---|-------------------------|-------------------|
| 33 kV Town-2 Feeder | 95,94,298 | 99,87,757 | 120 | 472.15 |
| | Reading as on 1 st January 2018 | Reading as on 1 st April 2019 | Multiplying Factor (MF) | Input Energy (LU) |
| | 22,104 | 1,30,057 | 120 | 129.54 |
| Total input energy for 33 kV Town - 2 feeder = (129.54 + 472.15 + 41.67) | | | | 643.37 |



Billed units of all 11 kV feeders can be summed up as per the list of feeder codes⁶. Billed units for 11 kV feeders are added from database files and the results are collated below –

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--|-----------------------|-----------------------------|--------------------------|
| 11 kV Udit Nagar feeder | 136.53 | 20.27 | 156.80 |
| 11 kV Main Road feeder | 127.63 | 67.20 | 194.83 |
| 11 kV Power house road | 64.14 | - | 64.14 |
| 11 kV Plant Site feeder | 118.56 | 2.22 | 120.78 |
| Total energy billed for connected consumers of 11 kV feeders | | | 536.56 |
| Total input energy for 33 kV Town - 2 feeder | | | 643.37 |
| Billing efficiency (%) | | | 83.40 % |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Udit Nagar feeder | 832.36 | 125.80 | 791.79 | 125.80 |
| 11 kV Main Road feeder | 785.06 | 428.58 | 745.71 | 428.58 |
| 11 kV Power house road | 369.39 | - | 391.97 | - |
| 11 kV Plant Site feeder | 668.76 | 17.89 | 588.25 | 17.89 |
| Total | | 3227.84 | | 3089.99 |
| Collection efficiency (%) | | | | 95.73 % |

⁶ List of 11 kV feeders with feeder codes provided by WESCO – Annexure 1

Therefore AT&C loss for 33 kV Town - 2 feeder can be calculated as follows:

| Parameter | Value |
|---------------------------|----------------|
| Billing efficiency (%) | 83.40% |
| Collection efficiency (%) | 95.73% |
| AT&C Loss | 20.16 % |

It may be noted that according to PFC guidelines Collection efficiency shall be considered not more than 100% while computing AT&C losses.

33 kV Basanti feeder

The input energy recorded for 33 kV Basanti feeder can be summed up and compared with 11 kV feeders emanating from 33/11 kV Basanti substation in order to determine loss on 33 kV line and power transformer loss.

From May 2018 onwards Basanti feeder started drawing power from 33kV Town 1 feeder as it was commissioned and charged on the same month. The total energy input to 33kV Town 1 feeder is a sum of power drawn by 11kV Nayabazar and 33kV Basanti feeder.

The quantum of energy drawn by 11kV Nayabazar feeder from 33kV town 1 is equal to that of 11kV Bondamunda feeder emanating from 33/11kV Bondamunda Substation (11kV Nayabazar and Bondamunda were connected from May 2018).


Therefore the calculation stands as:

$$\text{Input to 33kV Basanti feeder} = (\text{Consumption of 33kV Basanti feeder} + \text{Consumption of 33kV Town 1}) - \text{Consumption of 11kV Bondamunda feeder}$$

The input energy for Basanti 33kV is thus taken as a sum of the individual meter readings.

| Feeder Name | Reading on 1 st April 2018 | Reading on 1 st April 2019 | Multiplying Factor (MF) | Input Energy (LU) |
|--|---|--|-------------------------|-------------------|
| 33 kV Basanti feeder | 7,17,909 | 15,01,286 | 60 | 293.46 |
| Feeder Name | Reading on 1 st May 2018 | Reading on 1 st April 2019 | Multiplying Factor (MF) | Input Energy (LU) |
| Town-1(old REC) | 89,12,658 | 90,63,322 | 120 | 180.80 |
| Feeder Name | Consumption on 1 st May 2018 (Units) | Cumulative consumption till 1 st April 2019 (Units) | | Input Energy (LU) |
| 11kV Bondamunda feeder | 613800 | 9241200 | | 98.55 |
| Total input energy for 33 kV Basanti feeder (293.46 + 180.80 - 98.55) | | | | 392.01 |

It must be noted that the meter readings at 11kV Bonamunda feeder were unavailable. The consumption is calculated from load survey by MRT Rourkela



Billed units of all 11 kV feeders can be summed up as per the list of feeder codes. Billed units for 11 kV feeders are added from database files and the results are collated below –

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--|-----------------------|-----------------------------|--------------------------|
| 11 kV DAV feeder | 127.00 | - | 127.00 |
| 11 kV PHD feeder | 0.40 | 15.37 | 15.76 |
| 11 kV MS Palli feeder | 133.45 | 1.48 | 134.92 |
| Total energy billed for connected consumers of 11 kV feeders | | | 277.69 |
| Total input energy for 33 kV Basanti & Town 1 feeder | | | 392.01 |
| Billing efficiency (%) | | | 70.84% |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV DAV feeder | 606.12 | - | 553.30 | - |
| 11 kV PHD feeder | 1.87 | 87.19 | 1.51 | 87.19 |
| 11 kV MS Palli feeder | 622.47 | 8.80 | 342.16 | 8.80 |
| Total | | 1326.46 | | 992.96 |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| Collection efficiency (%) | | | | 74.86% |


Therefore AT&C loss for 33 kV Basanti & Town – 1 feeder can be calculated as follows:

| Parameter | Value |
|---------------------------|---------------|
| Billing efficiency (%) | 70.84% |
| Collection efficiency (%) | 74.86% |
| AT&C Loss | 46.97% |

33 kV Chhend-Koelnagar feeder

The input energy recorded for 33 kV Chhend-Koelnagar feeder can be summed up and compared with 11 kV feeders emanating from 33/11 kV Chhend and 33/11 kV Koelnagar substations in order to determine loss on 33 kV line and power transformer loss.

| Feeder Name | Reading on 1 st April 2018 | Reading on 1 st April 2019 | Multiplying Factor (MF) | Input Energy (LU) |
|---|---------------------------------------|---------------------------------------|-------------------------|-------------------|
| 33 kV Chhend-Koelnagar | 187,21,100 | 1,92,90,500 | 120 | 683.28 |
| Total input energy for 33 kV Chhend-Koelnagar feeder | | | | 683.28 |



Billed units of all 11 kV feeders can be summed up as per the list of feeder codes. Billed units for 11 kV feeders are added from database files and the results are collated below –

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--|-----------------------|-----------------------------|--------------------------|
| 11 kV Jhirpani feeder | 46.95 | 5.58 | 52.53 |
| 11 kV BC Block feeder | 52.17 | 0.00 | 52.17 |
| 11 kV ADE Block feeder | 79.45 | 0.00 | 79.45 |
| 11 kV Hamirpur feeder | 35.43 | 0.00 | 35.43 |
| 11 kV Self Finance feeder | 60.93 | 1.43 | 62.36 |
| 11 kV Panposh feeder | 55.34 | 3.21 | 58.54 |
| 11 kV RDA feeder | 41.63 | 2.64 | 44.27 |
| 11 kV Chhend 1 st Phase | 80.41 | 0.00 | 80.41 |
| 11 kV Kalinga Vihar | 67.88 | 0.00 | 67.88 |
| 11 kV Luhakera | 23.06 | 5.67 | 28.73 |
| Total energy billed for connected consumers of 11 kV feeders | | | 561.76 |
| Total input energy for 33 kV Chhend-Koelnagar feeder | | | 683.28 |
| Billing efficiency (%) | | | 82.22 % |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|------------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Jhirpani feeder | 234.25 | 35.86 | 189.49 | 35.86 |
| 11 kV BC Block feeder | 260.53 | - | 240.40 | - |
| 11 kV ADE Block feeder | 415.40 | - | 387.78 | - |
| 11 kV Hamirpur feeder | 163.53 | - | 145.52 | - |
| 11 kV Self Finance feeder | 307.60 | 12.73 | 322.43 | 12.73 |
| 11 kV Panposh feeder | 284.98 | 23.35 | 262.75 | 23.35 |
| 11 kV RDA feeder | 197.18 | 19.43 | 206.21 | 19.43 |
| 11 kV Chhend 1 st Phase | 396.40 | - | 403.74 | - |
| 11 kV Kalinga Vihar | 328.35 | - | 332.86 | - |
| 11 kV Luhakera | 118.59 | 24.89 | 87.28 | 24.89 |
| Total | | 2823.05 | | 2694.70 |
| Collection efficiency (%) | | | | 95.45 % |

Therefore AT&C loss for 33 kV Chhend-Koelnagar feeder can be calculated as follows:

| Parameter | Value |
|---------------------------|---------------|
| Billing efficiency (%) | 82.22% |
| Collection efficiency (%) | 95.45% |
| AT&C Loss | 21.52% |


11 kV Input point feeder-wise losses

11 kV Modern India - 1 feeder

11 kV Modern India – 1 feeder emanates from 33/11 kV Lathikata substation which in turn is supplied power through 33 kV Lathikata feeder from 132/33 kV Rourkela GSS. While other feeders from 33/11 kV Lathikata substation cater to areas outside smart city, 11 kV Modern India – 1 (partially) caters to Rourkela Smart city area. Input energy of the feeder is calculated as follows:

The total transformation capacity installed on the feeder is 8000kVA, out of that around 800kVA of transformation capacity falls under the smart city area. Therefore the input billing and collection is proportioned to be 10% of the total figures of the feeder as whole.

| Feeder Name | Input Energy (LU) |
|-------------------------------|-------------------|
| 11 kV Modern India - I feeder | 11.98 |



Billed units for the feeder can be derived by adding up LT billed energy from LT billing database provided by DFMs and HT billed energy from HT billing database provided by MRT division.

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--|-----------------------|-----------------------------|--------------------------|
| 11 kV Modern India - I (AIAA) | 9.52 | - | 9.52 |
| Total input energy for 11 kV Modern India - 1 feeder | | | 11.98 |
| Billing efficiency (%) | | | 79.47% |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Modern India - I (AIAA) | 36.36 | - | 36.05 | - |
| Total | | 36.36 | | 36.05 |
| Collection efficiency (%) | | | | 99.15% |

Therefore AT&C loss for 11 kV Modern India – 1 feeder can be calculated as follows:

| Parameter | Value |
|--|----------------|
| Billing efficiency (%) | 79.47 % |
| Collection efficiency (%) (Capped at 100%) | 99.15 % |
| AT&C Loss | 21.21 % |

11 kV Ved Vyas feeder

11 kV Vedvyas feeder emanates from 33/11 kV Vedvyas substation which in turn is supplied power through 33 kV Vedvyas feeder from 132/33 kV Chhend GSS. While other feeders from 33/11 kV Vedvyas substation cater to areas outside smart city, 11 kV Vedvyas and 11 kV Gopapalli feeders caters to Rourkela Smart city area. Input energy of the feeder is calculated as follows:


The Meter for Vedvyas feeder was defective from February Mid and was replaced afterwards. However the readings for the months of March and April could not be recorded and is thus taken on the basis of average consumption of the last 10 months.

Total For 10 Months:103.39 LU

Average per month: 10.34 LU

Consumption for February and March - (2X10.34=20.68)

| Feeder Name | Reading on 1 st April 2018 | Reading on 1 st Feb 2019 | Multiplying Factor (MF) | Input Energy (LU) |
|--|---------------------------------------|-------------------------------------|-------------------------|-------------------|
| 11 kV Vedvyas feeder | 5,867.71 | 6384.66 | 20000 | 103.39 |
| Consumption for February and March | | | | 20.68 |
| Total input energy for 11 kV Vedvyas feeder | | | | 124.07 |



Billed units for the feeder can be derived by adding up LT billed energy from LT billing database provided by DFMs and HT billed energy from HT billing database provided by MRT division.

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|---|-----------------------|-----------------------------|--------------------------|
| 11 kV Vedvyas (BDCC) | 70.00 | 26.44 | 96.44 |
| Total input energy for 11 kV Vedvyas feeder | | | 124.07 |
| Billing efficiency (%) | | | 77.73 % |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Vedvyas (BDCC) | 508.80 | 178.93 | 482.09 | 178.93 |
| Total | | 687.73 | | 661.02 |
| Collection efficiency (%) | | | | 96.12 % |

Therefore AT&C loss for 11 kV Vedvyas feeder can be calculated as follows:

| Parameter | Value |
|---------------------------|----------------|
| Billing efficiency (%) | 77.73 % |
| Collection efficiency (%) | 96.12 % |
| AT&C Loss | 25.29 % |

11 kV Gopapalli feeder

11 kV Gopapalli feeder emanates from 33/11 kV Vedvyas substation which in turn is supplied power through 33 kV Vedvyas feeder from 132/33 kV Chhend GSS. While other feeders from 33/11 kV Vedvyas substation cater to areas outside smart city, 11 kV Vedvyas and 11 kV Gopapalli feeders caters to Rourkela Smart city area. Input energy of the feeder is calculated as follows:


The Meter for Gopapalli feeder was defective from February Mid and was replaced afterwards. However the readings for the months of March and April could not be recorded and is thus taken on the basis of average consumption of the last 10 months.

Total for 10 months: 103.39 LU

Average per month: 10.34 LU

Consumption for February and March - (2X10.34=20.68)

| Feeder Name | Reading on 1 st April 2018 | Reading on 1 st April 2019 | Multiplying Factor (MF) | Input Energy (LU) |
|--|---------------------------------------|---------------------------------------|-------------------------|-------------------|
| 11 kV Gopapalli feeder | 11,340.44 | 11,608.01 | 20000 | 53.51 |
| Consumption for February and March | | | | 10.70 |
| Total input energy for 11 kV Gopapalli feeder | | | | 64.22 |



Billed units for the feeder can be derived by adding up LT billed energy from LT billing database provided by DFMs and HT billed energy from HT billing database provided by MRT division.

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|---|-----------------------|-----------------------------|--------------------------|
| 11 kV Gopapalli (BDCB) | 34.87 | 7.25 | 42.12 |
| Total input energy for 11 kV Gopapalli feeder | | | 64.22 |
| Billing efficiency (%) | | | 65.60 % |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Gopapalli (BDCB) | 211.20 | 51.77 | 174.94 | 51.77 |
| Total | 262.97 | | 226.71 | |
| Collection efficiency (%) | | | | 86.21 % |

Therefore AT&C loss for 11 kV Gopapalli feeder can be calculated as follows:

| Parameter | Value |
|---------------------------|----------------|
| Billing efficiency (%) | 64.22 % |
| Collection efficiency (%) | 86.21 % |
| AT&C Loss | 43.45 % |

11 kV Nayabazar feeder

11 kV Nayabazar feeder emanates from 33/11 kV REC substation which in turn is supplied power through 33 kV NIT feeder from 132/33 kV Chhend GSS. All three feeders from 33/11 kV REC substation cater to areas within smart city.


The Meter installed at 11kV Nayabazar feeder was defective from January 2019 onwards. Consumption of these three months is calculated on the basis of average consumption per month derived from meter readings till January 1st 2019.

$$\begin{aligned}
 \text{Total Input till January 1st} &= (\text{IMR April 2018} - \text{FMR January 2019}) * M.F \\
 \text{Total Input upto January 2019} &= (63893.19 - 63167.79) \times 4000 = 2893600 \\
 \text{Input for the months January, February \& March} &= \frac{2893600}{9} \times 3 = 964533
 \end{aligned}$$

From May 2018 11kV Nayabazar feeder started drawing power from 11kV Bondamunda feeder. Input energy of 11 kV Nayabazar feeder is calculated as follows:

Input energy to 11kV Nayabazar feeder = Consumption of 11kV Nayabazar Feeder + Consumption of 11kV Bondamunda Feeder

| Feeder Name | Reading on 1 st April 2018 | Reading on 1 st January 2019 | Multiplying Factor (MF) | Input Energy (LU) |
|---|---------------------------------------|---|-------------------------|-------------------|
| 11 kV Nayabazar feeder | 63,169.79 | 63,893.19 | 4000 | 28.94 |
| Consumption for the months January February and March | | | | 9.65 |
| Consumption of 11kV Bondamunda feeder | | | | 98.55 |
| Total input energy for 11 kV Nayabazar feeder | | | | 137.14 |



Billed units for the feeder can be derived by adding up LT billed energy from LT billing database provided by DFMs and HT billed energy from HT billing database provided by MRT division.

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|---|-----------------------|-----------------------------|--------------------------|
| 11 kV Nayabazar (AAAA) | 113.95 | 4.96 | 118.91 |
| Total input energy for 11 kV Nayabazar feeder | | | 137.14 |
| Billing efficiency (%) | | | 86.71 % |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Nayabazar (AAAA) | 523.42 | 25.55 | 432.75 | 25.55 |
| Total | | 548.98 | | 458.31 |
| Collection efficiency (%) | | | | 83.48 % |


Therefore AT&C loss for 11 kV Nayabazar feeder can be calculated as follows:

| Parameter | Value |
|---------------------------|----------------|
| Billing efficiency (%) | 86.71 % |
| Collection efficiency (%) | 83.48 % |
| AT&C Loss | 27.61 % |

11 kV OSAP feeder

11 kV OSAP feeder emanates from 33/11 kV REC substation which in turn is supplied power through 33 kV NIT feeder from 132/33 kV Chhend GSS. All three feeders from 33/11 kV REC substation cater to areas within smart city. Input energy of 11 kV OSAP feeder is calculated as follows:

| Feeder Name | Reading on 1 st April 2018 | Reading on 1 st April 2019 | Multiplying Factor (MF) | Input Energy (LU) |
|---|---------------------------------------|---------------------------------------|-------------------------|-------------------|
| 11 kV OSAP feeder | 30,920.86 | 32743.51 | 6000 | 109.36 |
| Total input energy for 11 kV OSAP feeder | | | | 109.36 |



Billed units for the feeder can be derived by adding up LT billed energy from LT billing database provided by DFMs and HT billed energy from HT billing database provided by MRT division.

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--|-----------------------|-----------------------------|--------------------------|
| 11 kV OSAP (AAAD) | 67.78 | - | 67.78 |
| Total input energy for 11 kV OSAP feeder | | | 109.36 |
| Billing efficiency (%) | | | 61.98% |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV OSAP (AAAD) | 329.40 | - | 252.71 | - |
| Collection efficiency (%) | | | | 76.72 % |


Therefore AT&C loss for 11 kV OSAP feeder can be calculated as follows:

| Parameter | Value |
|---------------------------|----------------|
| Billing efficiency (%) | 61.98 % |
| Collection efficiency (%) | 76.72 % |
| AT&C Loss | 52.45 % |

11 kV Shaktinagar feeder

11 kV Shaktinagar feeder emanates from 33/11 kV REC substation which in turn is supplied power through 33 kV NIT feeder from 132/33 kV Chhend GSS. All three feeders from 33/11 kV REC substation cater to areas within smart city. Input energy of 11 kV Shaktinagar feeder is calculated as 95.38 LU. It must be noted that the meter at Shaktinagar feeder was defective from December 2017. The input is provided by MRT WESCO Rourkela based on the previous year consumption and load growth:

| Feeder Name | Input Energy (LU) |
|-------------------|-------------------|
| 11 kV Shaktinagar | 95.38 |



Billed units for the feeder can be derived by adding up LT billed energy from LT billing database provided by DFMs and HT billed energy from HT billing database provided by MRT division.

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--------------------------|-----------------------|-----------------------------|--------------------------|
| 11 kV Shaktinagar (AAAB) | 77.87 | 2.47 | 80.34 |

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|---|-----------------------|-----------------------------|--------------------------|
| Total input energy for 11 kV Shaktinagar feeder | | | 95.38 |
| Billing efficiency (%) | | | 84.23 % |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Shaktinagr (AAAB) | 408.83 | 16.23 | 394.99 | 16.23 |
| Collection efficiency (%) | | | | 96.74 % |

Therefore AT&C loss for 11 kV Shaktinagar feeder can be calculated as follows:

| Parameter | Value |
|---------------------------|----------------|
| Billing efficiency (%) | 84.23 % |
| Collection efficiency (%) | 96.74 % |
| AT&C Loss | 18.51 % |

It may be noted that according to the guidelines Collection efficiency shall be considered not more than 100% while computing AT&C losses.

Total Input energy into the smart city area

| Sl. No. | Feeder Name | Input Energy (LU) |
|---------|--------------------------------|-------------------|
| 1 | 33 kV Industrial Estate feeder | 227.95 |
| 2 | 33 kV Pilot Project feeder | 37.45 |
| 3 | 33 kV Old IDC feeder | 437.98 |
| 4 | 33 kV Town - 2 feeder | 643.37 |
| 5 | 33 kV Basanti feeder | 293.46 |
| 6 | 33 kV Town-1 feeder | 98.55 |
| 7 | 33 kV Chhend-Koelnagar feeder | 683.28 |

| Sl. No. | Feeder Name | Input Energy (LU) |
|---|-------------------------------|-------------------|
| 8 | 11 kV Modern India - I feeder | 11.98 |
| 9 | 11 kV Vedvyas feeder | 124.07 |
| 10 | 11 kV Gopapalli feeder | 64.22 |
| 11 | 11 kV Nayabazar feeder | 137.14 |
| 12 | 11 kV OSAP feeder | 109.36 |
| 13 | 11 kV Shaktinagar feeder | 95.38 |
| Total input energy for Rourkela smart city area (FY 2018-19 till Feb'19) | | 2,964.18 |

Billed energy booked under the smart city area:

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--------------------------------|-----------------------|-----------------------------|--------------------------|
| 11 kV Pilot Project (Town) | 3.33 | 1.09 | 4.42 |
| 11 kV Industrial Estate feeder | 123.56 | 6.40 | 129.96 |
| 11 kV Town feeder | 38.06 | 15.41 | 53.47 |
| 11 kV PHD feeder | 0.42 | 15.37 | 15.79 |
| 11 kV Raw Water feeder | 24.29 | 32.88 | 57.17 |
| 11 kV College feeder | 92.82 | 29.38 | 122.20 |
| 11 kV Town feeder | 161.56 | 0.00 | 161.56 |
| 11 kV RGH feeder | 0.00 | 0.00 | 0.00 |
| 11 kV Udit Nagar feeder | 136.53 | 20.27 | 156.80 |
| 11 kV Main Road feeder | 127.63 | 67.20 | 194.83 |
| 11 kV Power house road | 64.14 | 0.00 | 64.14 |
| 11 kV Plant Site feeder | 118.56 | 2.22 | 120.78 |
| 11 kV DAV feeder | 127.00 | 0.00 | 127.00 |
| 11 kV PHD feeder | 0.40 | 15.37 | 15.76 |
| 11 kV MS Palli feeder | 133.45 | 1.48 | 134.92 |
| 11 kV Jhirpani feeder | 46.95 | 5.58 | 52.53 |
| 11 kV BC Block feeder | 52.17 | - | 52.17 |
| 11 kV ADE Block feeder | 79.45 | - | 79.45 |

| Feeder Name | LT billed energy (LU) | 11 kV HT billed energy (LU) | Total billed energy (LU) |
|--|-----------------------|-----------------------------|--------------------------|
| 11 kV Hamirpur feeder | 35.43 | - | 35.43 |
| 11 kV Self Finance feeder | 60.93 | 1.43 | 62.36 |
| 11 kV Panposh feeder | 55.34 | 3.21 | 58.54 |
| 11 kV RDA feeder | 41.63 | 2.64 | 44.27 |
| 11 kV Chhend 1 st Phase | 80.41 | - | 80.41 |
| 11 kV Kalinga Vihar | 67.88 | - | 67.88 |
| 11 kV Luhakera | 23.06 | 5.67 | 28.73 |
| 11 kV Modern India - I (AIAA) | 9.52 | - | 9.52 |
| 11 kV Vedvyas (BDCC) | 70.00 | 26.44 | 96.44 |
| 11 kV Gopapalli (BDCB) | 34.87 | 7.25 | 42.12 |
| 11 kV Nayabazar (AAAA) | 113.95 | 4.96 | 118.91 |
| 11 kV OSAP (AAAD) | 67.78 | - | 67.78 |
| 11 kV Shaktinagar (AAAB) | 77.87 | 2.47 | 80.34 |
| Total LT & 11 kV HT | 2068.99 | 266.72 | 2335.70 |
| Total energy billed for connected consumers of 11 kV feeders | | | 2335.70 |
| Billed energy for 33 kV consumers and DT | | | 60.99 |
| Total billed energy 33 kV consumer + 11 kV feeders | | | 2,396.70 |
| Total input energy | | | 2,964.18 |
| Billing efficiency (%) | | | 80.86% |

Billed units for HT consumers

| Sl. No. | Consumer Name | Billed Energy (LU) |
|---------|--------------------------------|--------------------|
| 1 | Utkal Flour Mills | 18.80 |
| 2 | Project Manager (PMU) | 33.47 |
| 3 | 33/0.4 kV Balughat transformer | 8.73 |

Collection booked under the smart city area

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|------------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 33 kV Utkal Flour Mill | - | 118.92 | - | 118.92 |
| 33 kV Project Manager PMU | - | 189.10 | - | 189.10 |
| 33/0.4 kV Balughat (AGLX) | 48.98 | 0.00 | 56.63 | 0.00 |
| 11 kV Pilot Project (Town) | 24.60 | 6.59 | 27.09 | 6.59 |
| 11 kV Industrial Estate feeder | 710.36 | 44.22 | 687.54 | 44.22 |
| 11 kV Town feeder | 235.90 | 106.64 | 209.02 | 106.64 |
| 11 kV PHD feeder | 1.99 | 87.19 | 2.24 | 87.19 |
| 11 kV Raw Water feeder | 134.35 | 196.62 | 128.88 | 196.62 |
| 11 kV College feeder | 572.95 | 199.18 | 581.54 | 199.18 |
| 11 kV Town feeder | 959.25 | 0.00 | 974.35 | 0.00 |
| 11 kV RGH feeder | - | - | - | - |
| 11 kV DAV feeder | 606.12 | - | 553.30 | - |
| 11 kV PHD feeder | 1.87 | 87.19 | 1.51 | 87.19 |
| 11 kV MS Palli feeder | 622.47 | 8.80 | 342.16 | 8.80 |
| 11 kV Jhirpani feeder | 234.25 | 35.86 | 189.49 | 35.86 |
| 11 kV BC Block feeder | 260.53 | - | 240.40 | - |
| 11 kV ADE Block feeder | 415.40 | - | 387.78 | - |
| 11 kV Hamirpur feeder | 163.53 | - | 145.52 | - |
| 11 kV Self Finance feeder | 307.60 | 12.73 | 322.43 | 12.73 |
| 11 kV Panposh feeder | 284.98 | 23.35 | 262.75 | 23.35 |
| 11 kV RDA feeder | 197.18 | 19.43 | 206.21 | 19.43 |
| 11 kV Chhend 1 st Phase | 396.40 | - | 403.74 | - |
| 11 kV Kalinga Vihar | 328.35 | - | 332.86 | - |
| 11 kV Luhakera | 118.59 | 24.89 | 87.28 | 24.89 |
| 11 kV Udit Nagar feeder | 832.36 | 125.80 | 791.79 | 125.80 |
| 11 kV Main Road feeder | 785.06 | 428.58 | 745.71 | 428.58 |
| 11 kV Power house road | 369.39 | | 391.97 | |
| 11 kV Plant Site feeder | 668.76 | 17.89 | 588.25 | 17.89 |
| 11kV Modern India 1 | 36.36 | | 36.05 | |
| 11 kV Vedvyas (BDCC) | 508.80 | 178.93 | 482.09 | 178.93 |
| 11 kV Gopapalli (BDCCB) | 211.20 | 51.77 | 174.94 | 51.77 |

| Feeder / Consumer Name | LT billed amount (INR Lacs) | HT billed amount (INR Lacs) | LT collected amount (INR Lacs) | HT collected amount (INR Lacs) |
|----------------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|
| 11 kV Nayabazar (AAAA) | 523.42 | 25.55 | 432.75 | 25.55 |
| 11 kV OSAP (AAAD) | 329.40 | - | 252.71 | - |
| 11 kV Shaktinagar | 408.83 | 16.23 | 394.99 | 16.23 |
| Total | 11299.22 | 2005.44 | 10433.96 | 2005.44 |
| Collection efficiency (%) | | | | 93.50% |

The total AT&C losses, input feeder wise in the Smart City area as a whole under WESCO Rourkela circle for FY 2018-19 is tabulated below:

| Sl. No. | Feeder Name | Input Energy (LU) | Billed Units | Billed amount | Collected amount | Billing Efficiency | Collection Efficiency | AT&C Losses |
|--|--------------------------------|-------------------|-----------------|------------------|------------------|--------------------|-----------------------|---------------|
| 1 | 33 kV Industrial Estate feeder | 227.95 | 206.66 | 1247.23 | 1200.02 | 77.87% | 96.21% | 25.08% |
| 2 | 33 kV Pilot Project feeder | 37.45 | | | | | | |
| 3 | 33 kV Old IDC feeder | 437.99 | 398.92 | 2389.61 | 2415.73 | 91.08% | 101.09% | 8.92% |
| 4 | 33 kV Town - 2 feeder | 643.37 | 536.56 | 3227.84 | 3089.99 | 83.40% | 95.73% | 20.16% |
| 5 | 33 kV Basanti feeder | 293.46 | 277.69 | 1326.46 | 992.96 | 70.84% | 74.86% | 46.97% |
| 6 | 33 kV Town-1 feeder | 98.55 | | | | | | |
| 7 | 33 kV Chhend-Koelnagar feeder | 683.28 | 561.76 | 2823.05 | 2694.70 | 82.22% | 95.45% | 21.52% |
| 8 | 11 kV Modern India - I feeder | 11.98 | 9.52 | 36.36 | 36.05 | 79.47% | 99.15% | 21.21% |
| 9 | 11 kV Vedvyas feeder | 124.07 | 96.44 | 687.73 | 661.02 | 77.73% | 96.12% | 25.29% |
| 10 | 11 kV Gopapalli feeder | 64.22 | 42.12 | 262.97 | 226.71 | 65.60% | 86.21% | 43.45% |
| 11 | 11 kV Nayabazar feeder | 137.14 | 118.91 | 548.98 | 458.31 | 86.71% | 83.48% | 27.61% |
| 12 | 11 kV OSAP feeder | 109.36 | 67.78 | 329.40 | 252.71 | 61.98% | 76.72% | 52.45% |
| 13 | 11 kV Shaktinagar feeder | 95.38 | 80.34 | 425.05 | 411.21 | 84.23% | 96.74% | 18.51% |
| Total for Rourkela smart city area (FY 2018-19) | | 2,964.18 | 2,396.70 | 13,304.66 | 12,439.40 | 80.86% | 93.50% | 24.40% |

Technical loss verification

Calculation of technical losses

Data regarding line length, location of consumers and substations, conductor size, peak load etc. have been obtained from WESCO in order to calculate the technical losses in line.

Load factor of each line can be calculated using the following formula-

$$\text{Load Factor (LF)} = \frac{\text{Average Demand}}{\text{Maximum Demand}} \times 100 \quad (\%)$$

Since the peak load of all feeders can be calculated in Amperes, we can use the same to determine peak power losses. However, for all periods of time, the I²R losses cannot be calculated at peak demand. Therefore, Loss Load Factor (LLF) has been introduced to estimate the actual losses on feeder. LLF is calculated as follows –

$$\text{Loss Load Factor (LLF)} = 0.8 \times \text{LF}^2 + 0.2 \times \text{LF}$$

Now, to calculate the peak I²R losses, Resistance (R) can be calculated as for each section as -

$$\text{Resistance of line (R)} = 3 \times r \times L$$

where r is the rated resistance of conductor in Ω (ohm) /km and L is the length

Standard resistance of conductors and cables are listed below for reference –

| Conductor / Cable type | Conductor / Cable size | Standard AC resistance (Ω /km) at 75°C ⁷ | Usage in Rourkela |
|------------------------|-----------------------------|---|-------------------|
| AAAC Conductor | Rabbit 55 mm ² | 0.7230 | Max 11 kV feeders |
| AAAC Conductor | Dog 100 mm ² | 0.3955 | - |
| ACSR Conductor | Rabbit 50 mm ² | 0.7761 | - |
| ACSR Conductor | Racoon 80 mm ² | 0.5216 | Max 33 kV feeders |
| ACSR Conductor | Dog 100 mm ² | 0.3924 | - |
| ACSR Conductor | Panther 200 mm ² | 0.1706 | - |
| XLPE Underground Cable | 185 mm ² | 0.2110 | - |
| XLPE Underground Cable | 240 mm ² | 0.1620 | - |
| XLPE Underground Cable | 630 mm ² | 0.0600 | - |
| Aerial Bunched Cable | 70 mm ² | 0.5670 | - |

⁷ As per IS 398 (Part II) & IS 8130

| Conductor / Cable type | Conductor / Cable size | Standard AC resistance (Ω /km) at 75°C ⁷ | Usage in Rourkela |
|------------------------|------------------------|---|-------------------|
| Aerial Bunched Cable | 90 mm ² | 0.4100 | - |

Table 5 - Standard resistance by conductor / cable type

Further, the peak power losses can be calculated for each section as follows –

$$\text{Peak power losses (P)} = I^2R \text{ (Watts)}$$

where I is the peak load of feeder in Amperes (A)

Now, the total technical losses of the feeder can be evaluated as summation of section-wise losses follows –

$$\text{Technical loss (T)} = \sum \frac{\text{LLF} \times P \times 24 \text{ hours} \times 365}{1000} \text{ kWh}$$

Based on the above methodology, voltage level-wise technical losses have been calculated 33 kV feeders

a) 33 kV Basanti feeder




Figure 10 - SLD of 33 kV Basanti feeder

33 / 11 kV Basanti substation has 2 x 8 MVA power transformers with 3 nos. 11 kV feeders catering to Rourkela smart city area. Peak load of the feeder is about 11,920 kVA as per data shared by MRT division. Average power factor is 0.99 as determined from meter data during pf profiling.

$$\text{Peak load in Amps} = 11,920 / (1.732 \times 33 \times 0.99) = 211 \text{ Amp.}$$

$$I^2R \text{ loss} = 211^2 \times 0.5216 \times 3 \times 4 \text{ km} = 278 \text{ kW}$$

$$\text{Energy at peak demand for one year} = 11,920 \times 365 \times 24 \times 0.99 = 1033.75 \text{ LU}$$

$$\text{Energy input on feeder during FY 2017-18} = 470.03 \text{ LU}$$

Therefore, load factor = 0.45

$$\text{LLF} = 0.8 \times 0.45^2 + 0.2 \times 0.45 = 0.26$$

$$\text{Thus technical loss} = 0.26 \times 278 \times 365 \times 24 = 6.24 \text{ LU}$$

% technical loss = 1.33 %

a. 33 kV Chhend-Koelnagar Feeder




Figure 11 - SLD of 33 kV Chhend - Koelnagar feeder

33 kV Chhend Koelnagar feeder provides supply to 33 / 11 kV Chhend and Koelnagar substations which have 18 MVA and 15 MVA power transformer capacities. There are total 10 nos. 11 kV feeders catering to Rourkela smart city area from these 2 substations. Peak load of the feeder is about 21,480 kVA as per data shared by MRT division. Average power factor is 0.95 as determined from meter data during pf profiling.

Peak load in Amps = $21,480 / (1.732 \times 33 \times 0.95) = 396$ Amp.

I^2R loss = $396^2 \times 0.5216 \times 3 \times 8 \text{ km} = 1,959$ kW

Energy at peak demand for one year = $21,480 \times 365 \times 24 \times 0.95 = 1787.57$ LU

Energy input on feeder during FY 2017-18 = 756.62 LU

Therefore, load factor = 0.42

LLF = $0.8 \times 0.42^2 + 0.2 \times 0.42 = 0.23$

Thus technical loss = $0.23 \times 1959 \times 365 \times 24 = 39.12$ LU

% technical loss = 5.17 %

b. 33 kV Old IDC (Civil Township feeder)




Figure 12 - SLD of 33 kV Old IDC Civil township feeder

33 kV Old IDC (Civil township) feeder provides supply to 33 / 11 kV Pamposh substation which has $2 \times 8 = 16$ MVA power transformer capacity. There are total 5 nos. 11 kV feeders (out of which 4 are operational at present) catering to Rourkela smart city area. Peak load of the feeder is about 9,200 kVA as per data gathered from substation in-charge (it was not available with MRT department). Average power factor is 0.94 as determined from meter data during pf profiling.

Peak load in Amps = $9,200 / (1.732 \times 33 \times 0.94) = 171$ Amp.

I^2R loss = $171^2 \times 0.5216 \times 3 \times 7 \text{ km} = 321$ kW

Energy at peak demand for one year = $9,200 \times 365 \times 24 \times 0.94 = 757.76$ LU

Energy input on feeder during FY 2017-18 = 359.03 LU

Therefore, load factor = 0.47

LLF = $0.8 \times 0.47^2 + 0.2 \times 0.47 = 0.27$

Thus technical loss = $0.27 \times 321 \times 365 \times 24 = 7.72$ LU

% technical loss = 2.15 %

c. 33 kV Powerhouse road (Town II) feeder




Figure 13 - SLD of 33 kV Powerhouse road (Town II) feeder

33 kV Powerhouse road (Town II) feeder provides supply to 33 / 11 kV Powerhouse road substation which has 1 x 8 + 2 x 5 = 18 MVA power transformer capacity. There are total 4 nos. 11 kV feeders catering to Rourkela smart city area. Peak load of the feeder is about 15,840 kVA as per data gathered from substation in-charge (it was not available with MRT department). Average power factor is 0.96 as determined from meter data during pf profiling.

Peak load in Amps = $15,840 / (1.732 \times 33 \times 0.96) = 289$ Amp.

I^2R loss = $289^2 \times 0.5216 \times 3 \times 0.5 \text{ km} = 65 \text{ kW}$

Energy at peak demand for one year = $15,840 \times 365 \times 24 \times 0.96 = 1,332.08 \text{ LU}$

Energy input on feeder during FY 2017-18 = 513.37 LU

Therefore, load factor = 0.39

LLF = $0.8 \times 0.39^2 + 0.2 \times 0.39 = 0.20$

Thus technical loss = $0.20 \times 65 \times 365 \times 24 = 1.12 \text{ LU}$

% technical loss = 0.22 %

d. 33 kV Industrial Estate feeder




Figure 14 - SLD of 33 kV Industrial Estate feeder

33 kV Industrial estate feeder provides supply to 33 / 11 kV Industrial estate substation which has 1 x 8 MVA power transformer capacity. There are total 2 nos. 11 kV feeders catering to Rourkela smart city area. Peak load of the 33 kV feeder is about 9,990 kVA as per data gathered from substation in-charge (it was not available with MRT department). Average power factor is 0.92 as determined from meter data during pf profiling.

Peak load in Amps = $9,990 / (1.732 \times 33 \times 0.92) = 190$ Amp.

I^2R loss = $190^2 \times 0.5216 \times 3 \times 5 \text{ km} = 282 \text{ kW}$

Energy at peak demand for one year = $9,990 \times 365 \times 24 \times 0.92 = 805.11 \text{ LU}$

Energy input on feeder during FY 2017-18 = 193.63 LU

Therefore, load factor = 0.24

LLF = $0.8 \times 0.24^2 + 0.2 \times 0.24 = 0.09$

Thus technical loss = $0.09 \times 282 \times 365 \times 24 = 2.33 \text{ LU}$

% technical loss = 1.20 %

e. 33 kV Pilot project feeder




Figure 15 - SLD of 33 kV Pilot project feeder

33 kV Pilot project feeder provides supply to 33 / 11 kV Pilot project substation which has 1.6 MVA power transformer capacity. There is only 1 nos. 11 kV feeder catering to Rourkela smart city area as well as 33 kV consumer "Utkal Floor mill". Peak load of the 33 kV feeder is about 10,800 kVA as per data gathered from substation in-charge (it was not available with MRT department). Average power factor is 0.88 as determined from meter data during pf profiling.

Peak load in Amps = $10,800 / (1.732 \times 33 \times 0.88) = 215$ Amp.

I^2R loss = $215^2 \times 0.5216 \times 3 \times 7 \text{ km} = 505 \text{ kW}$

Energy at peak demand for one year = $10,800 \times 365 \times 24 \times 0.88 = 832.55 \text{ LU}$

Energy input on feeder during FY 2017-18 = 21.80 LU

Therefore, load factor = 0.03

LLF = $0.8 \times 0.03^2 + 0.2 \times 0.03 = 0.01$

Thus technical loss = $0.01 \times 505 \times 365 \times 24 = 0.26 \text{ LU}$

% technical loss = 1.17 %

| Sl. No. | Feeder Name | Input Energy in FY 17-18 (LU) | Technical Loss in LU | % Technical loss |
|--|--|-------------------------------|----------------------|------------------|
| a. | 33 kV Basanti feeder | 470.03 | 6.24 | 1.33% |
| b. | 33 kV Chhend Koelnagar feeder | 756.62 | 39.12 | 5.17% |
| c. | 33 kV Old IDC (Civil township) feeder | 359.03 | 7.72 | 2.15% |
| d. | 33 kV Powerhouse road (Town II) feeder | 513.37 | 1.12 | 0.22% |
| e. | 33 kV Industrial Estate feeder | 193.63 | 2.33 | 1.20% |
| f. | 33 kV Pilot project feeder | 21.80 | 0.26 | 1.19% |
| Overall technical loss at 33 kV | | 2,314.48 | 56.79 | 2.45% |

Figure 16 - Summary of Technical losses at 33 kV level

11 kV feeders

Technical loss for 8 nos. sample 11 kV feeders have been evaluated using the same methodology as shared above.

a. 11 kV DAV feeder




Figure 17 - SLD of 11 kV DAV feeder

For each node in the 11 kV network, the technical loss per node is derived as follows:

| Start | End | Length (Ckt km) | DT Capacity (kVA) | Cummulative DT Capacity (kVA) | Peak current (A) @ 0.96 pf | Resistance (Ohms) | I ² R (kW) |
|----------------------------------|-----|-----------------|-------------------|-------------------------------|----------------------------|-------------------|-----------------------|
| J | K | 0.10 | 200 | 200 | 10.93 | 0.22 | 0.03 |
| I | J | 0.20 | 625 | 825 | 45.11 | 0.43 | 0.88 |
| I1 | I2 | 0.20 | 100 | 300 | 16.40 | 0.43 | 0.12 |
| I | I1 | 0.50 | 880 | 1180 | 64.51 | 1.08 | 4.51 |
| H | I | 0.20 | 0 | 825 | 45.11 | 0.43 | 0.88 |
| G | H | 0.50 | 600 | 1425 | 77.91 | 1.08 | 6.58 |
| F | G | 0.30 | 500 | 1925 | 105.25 | 0.65 | 7.21 |
| E | F | 0.20 | 100 | 2025 | 110.71 | 0.43 | 5.32 |
| E | E1 | 0.70 | 600 | 2625 | 143.52 | 1.52 | 31.27 |
| D | E | 0.10 | 0 | 2025 | 110.71 | 0.22 | 2.66 |
| C | D | 0.30 | 275 | 2300 | 125.75 | 0.65 | 10.29 |
| B | C | 0.20 | 315 | 2615 | 142.97 | 0.43 | 8.87 |
| A | B | 0.40 | 600 | 3215 | 175.77 | 0.87 | 26.81 |
| O | A | 0.20 | 200 | 3415 | 186.71 | 0.43 | 15.12 |
| Total technical loss (kW) | | | | | | | 120.55 |

Table 6 - Node-wise technical loss for DAV feeder

Energy at peak demand for one year = 3,415 x 365 x 24 x 0.96 = 287.19 LU

Energy input on feeder during FY 2017-18 = 140.04 LU

Therefore, load factor = 0.49

$$LLF = 0.8 \times 0.49^2 + 0.2 \times 0.49 = 0.29$$

Thus technical loss = 0.29 x 120.55 x 365 x 24 = 3.04 LU

% technical loss = 2.17 %

b. 11 kV BC feeder




Figure 18 - SLD of 11 kV BC Block feeder

For each node in the 11 kV network, the technical loss per node is derived as follows:

| Start | End | Length (Ckt Km) | DT Capacity (kVA) | Cumulative DT Capacity (kVA) | Peak current (A) @ 0.95 pf | Resistance (Ohms) | I ² R (W) |
|----------------------------------|-----|-----------------|-------------------|------------------------------|----------------------------|-------------------|----------------------|
| G | H | 0.40 | 815 | 815 | 45.03 | 0.93 | 1.89 |
| F | G | 0.64 | 625 | 1,440 | 79.56 | 1.49 | 9.43 |
| E | F | 0.40 | 478 | 1,918 | 105.97 | 0.93 | 10.46 |
| D | E | 0.70 | 250 | 2,168 | 119.78 | 1.63 | 23.38 |
| C | D | 0.01 | 25 | 2,193 | 121.16 | 0.02 | 0.34 |
| B | C | 0.01 | 63 | 2,256 | 124.64 | 0.02 | 0.36 |
| A | B | 0.02 | 100 | 2,356 | 130.17 | 0.05 | 0.79 |
| O | A | 0.20 | 413 | 2,769 | 152.98 | 0.47 | 10.90 |
| Total technical loss (kW) | | | | | | | 57.55 |

Table 7 - Node-wise technical loss for 11 kV BC feeder

Energy at peak demand for one year = 2,769 x 365 x 24 x 0.95 = 230.44 LU

Energy input on feeder during FY 2017-18 = 74.87 LU

Therefore, load factor = 0.32

$$LLF = 0.8 \times 0.32^2 + 0.2 \times 0.32 = 0.15$$

Thus technical loss = $0.15 \times 57.55 \times 365 \times 24 = 0.75$ LU

% technical loss = 1.00 %

c. 11 kV Jhirpani feeder




Figure 19 - SLD of 11 kV Jhirpani feeder

For each node in the 11 kV network, the technical loss per node is derived as follows:

| Start | End | Length (Ckt km) | DT Capacity (kVA) | Cumulative DT Capacity (kVA) | Peak current (A) @ 0.97 pf | Resistance (Ohms) | I ² R (W) |
|-------|-----|-----------------|-------------------|------------------------------|----------------------------|-------------------|----------------------|
| P | Q | 0.35 | 25 | 200 | 10.82 | 0.81 | 0.10 |
| O | P | 0.10 | 100 | 300 | 16.23 | 0.23 | 0.06 |
| L | O | 0.65 | 350 | 650 | 35.17 | 1.51 | 1.87 |
| K | L | 0.45 | 0 | 650 | 35.17 | 1.05 | 1.30 |
| L | M | 0.50 | 750 | 1400 | 75.75 | 1.16 | 6.68 |
| M | N | 0.02 | 25 | 1425 | 77.11 | 0.05 | 0.28 |
| F | K | 0.45 | 500 | 1925 | 104.16 | 1.05 | 11.37 |

| | | | | | | | |
|----------------------------------|---|------|-----|------|--------|------|---------------|
| F | G | 0.35 | 350 | 2275 | 123.10 | 0.81 | 12.35 |
| G | H | 0.07 | 0 | 2275 | 123.10 | 0.16 | 2.47 |
| H | I | 0.07 | 63 | 2338 | 126.51 | 0.16 | 2.61 |
| H | J | 0.40 | 100 | 2438 | 131.92 | 0.93 | 16.21 |
| C | F | 0.80 | 0 | 2438 | 131.92 | 1.86 | 32.42 |
| D | E | 0.10 | 100 | 2538 | 137.33 | 0.23 | 4.39 |
| C | D | 0.40 | 225 | 2763 | 149.51 | 0.93 | 20.82 |
| B | C | 0 | 0 | 2763 | 149.51 | - | - |
| A | B | 0.4 | 550 | 3313 | 179.27 | 0.93 | 29.93 |
| O | A | 1.2 | 25 | 3338 | 180.62 | 2.79 | 91.15 |
| Total technical loss (kW) | | | | | | | 233.98 |

Table 8 - Node-wise technical loss for 11 kV Jhirpani feeder

Energy at peak demand for one year = 3,338 x 365 x 24 x 0.97 = 283.64 LU

Energy input on feeder during FY 2017-18 = 91.13 LU

Therefore, load factor = 0.32

$$LLF = 0.8 \times 0.32^2 + 0.2 \times 0.32 = 0.15$$

Thus technical loss = 0.15 x 233.98 x 365 x 24 = 3.01 LU

% technical loss = 3.30 %

d. 11 kV Nayabazar




Figure 20 - SLD of 11 kV Nayabazar feeder

For each node in the 11 kV network, the technical loss L per node is derived as follows:

| Start | End | Length (Ckt km) | DT Capacity (kVA) | Cummulative DT Capacity (kVA) | Peak current (A) @ 0.83 pf | Resistance (Ohms) | I ² R (W) |
|-------|-----|-----------------|-------------------|-------------------------------|----------------------------|-------------------|----------------------|
| A13 | A14 | 0.70 | 100 | 200 | 12.65 | 1.63 | 0.26 |
| A12 | A13 | 0.20 | 63 | 263 | 16.63 | 0.47 | 0.13 |
| A11 | A12 | 0.40 | 363 | 626 | 39.59 | 0.93 | 1.46 |
| A10 | A11 | 0.70 | 16 | 642 | 40.60 | 1.63 | 2.69 |
| A9 | A10 | 0.10 | 100 | 742 | 46.92 | 0.23 | 0.51 |
| A8 | A9 | 0.40 | 263 | 1005 | 63.55 | 0.93 | 3.76 |
| A7 | A8 | 0.30 | 125 | 1130 | 71.46 | 0.70 | 3.57 |
| A7 | A71 | 0.15 | 50 | 1462 | 92.45 | 0.35 | 2.99 |
| A6 | A7 | 0.50 | 282 | 1412 | 89.29 | 1.16 | 9.28 |
| A5 | A6 | 0.20 | 489 | 1951 | 123.37 | 0.47 | 7.09 |
| A4 | A5 | 0.30 | 850 | 2801 | 177.13 | 0.70 | 21.91 |
| A3 | A4 | 0.10 | 63 | 2864 | 181.11 | 0.23 | 7.64 |

| Start | End | Length (Ckt km) | DT Capacity (kVA) | Cummulative DT Capacity (kVA) | Peak current (A) @ 0.83 pf | Resistance (Ohms) | I ² R (W) |
|----------------------------------|-----|-----------------|-------------------|-------------------------------|----------------------------|-------------------|----------------------|
| A2 | A3 | 0.10 | 413 | 3277 | 207.23 | 0.23 | 10.00 |
| A1 | A2 | 0.30 | 100 | 3377 | 213.55 | 0.70 | 31.85 |
| X | A1 | 0.2 | 25 | 3402 | 215.13 | 0.47 | 21.55 |
| T | X | 0.3 | 250 | 3652 | 230.94 | 0.70 | 37.25 |
| S | T | 0.3 | 100 | 3752 | 237.26 | 0.70 | 39.32 |
| R | S | 0.3 | 25 | 3777 | 238.84 | 0.70 | 39.85 |
| Q | R | 0.3 | 25 | 3802 | 240.43 | 0.70 | 40.38 |
| P | Q | 0.3 | 250 | 4052 | 256.23 | 0.70 | 45.86 |
| O | P | 0.4 | 200 | 4252 | 268.88 | 0.93 | 67.33 |
| N | O | 0.5 | 250 | 4502 | 284.69 | 1.16 | 94.35 |
| M | N | 0.3 | 307 | 4809 | 304.10 | 0.70 | 64.60 |
| L | M | 0 | 250 | 5059 | 319.91 | - | - |
| K1 | L | 0.5 | 200 | 5259 | 332.56 | 1.16 | 128.75 |
| K | K1 | 0.4 | 200 | 5459 | 345.21 | 0.93 | 110.98 |
| J | K | 0.5 | 250 | 5709 | 361.02 | 1.16 | 151.73 |
| I | J | 1 | 100 | 5809 | 367.34 | 2.33 | 314.18 |
| H | I | 0.6 | 100 | 5909 | 373.67 | 1.40 | 195.05 |
| G | H | 2 | 100 | 6009 | 379.99 | 4.66 | 672.37 |
| F | G | 1.5 | 63 | 6072 | 383.97 | 3.49 | 514.91 |
| E | F | 0.1 | 16 | 6088 | 384.98 | 0.23 | 34.51 |
| D | E | 0.7 | 315 | 6403 | 404.90 | 1.63 | 267.20 |
| C | D | 0.5 | 250 | 6653 | 420.71 | 1.16 | 206.05 |
| B1 | C | 0.3 | 1024 | 7677 | 485.47 | 0.70 | 164.62 |
| B1 | B1 | 0.05 | 63 | 7740 | 489.45 | 0.12 | 27.89 |
| A | B | 1 | 128 | 7868 | 497.55 | 2.33 | 576.37 |
| O | A | 0.5 | 128 | 7996 | 505.64 | 1.16 | 297.64 |
| Total technical loss (kW) | | | | | | | 4,215.89 |

Table 9 - Node-wise technical loss for 11 kV Nayabazar feeder

Energy at peak demand for one year = 7,996 x 365 x 24 x 0.83 = 581.37 LU

Energy input on feeder during FY 2017-18 = 147.30 LU

Therefore, load factor = 0.25

$$LLF = 0.8 \times 0.25^2 + 0.2 \times 0.25 = 0.10$$

Thus technical loss = 0.10 x 4215.89 x 365 x 24 = 37.38 LU

% technical loss = 25.38 %

e. 11 kV Plant Site feeder

SINGLE LINE DIAGRAM OF 11 KV PLANT SITE FEEDER OF 33/11 KV S/S P.H.ROAD, ROURKELA AS ON Mar'18




Figure 21 - SLD of 11 kV Plant site road feeder

For each node in the 11 kV network, the technical loss per node is derived as follows:

| Start | End | Length (Ckt km) | DT Capacity (kVA) | Cummulative DT Capacity (kVA) | Peak current (A) @ 0.98 pf | Resistance (Ohms) | I ² R (W) |
|-------|-----|-----------------|-------------------|-------------------------------|----------------------------|-------------------|----------------------|
| G | H | 0.20 | 0 | 0 | - | 0.47 | - |
| F | G | 0.20 | 750 | 750 | 40.17 | 0.47 | 0.75 |
| E | F | 0.30 | 500 | 1250 | 66.95 | 0.70 | 3.13 |
| D | E | 0.50 | 630 | 1880 | 100.69 | 1.16 | 11.80 |
| C | D | 0.20 | 730 | 2610 | 139.79 | 0.47 | 9.10 |
| B | C | 0.10 | 1000 | 3610 | 193.34 | 0.23 | 8.70 |
| B6 | B7 | 0.30 | 1000 | 4610 | 246.90 | 0.70 | 42.58 |
| B5 | B6 | 0.10 | 100 | 4710 | 252.26 | 0.23 | 14.82 |
| B4 | B5 | 0.20 | 16 | 4726 | 253.11 | 0.47 | 29.83 |
| B3 | B4 | 0.20 | 16 | 4742 | 253.97 | 0.47 | 30.04 |

| Start | End | Length (Ckt km) | DT Capacity (kVA) | Cummulative DT Capacity (kVA) | Peak current (A) @ 0.98 pf | Resistance (Ohms) | I ² R (W) |
|----------------------------------|-----|-----------------|-------------------|-------------------------------|----------------------------|-------------------|----------------------|
| B2 | B3 | 0.20 | 16 | 4758 | 254.83 | 0.47 | 30.24 |
| B1 | B2 | 0.20 | 16 | 4774 | 255.68 | 0.47 | 30.44 |
| B | B1 | - | 0 | 4774 | 255.68 | - | - |
| A | B | 0.60 | 516 | 5290 | 283.32 | 1.40 | 112.14 |
| A2 | 0.1 | 0.1 | 500 | 5790 | 310.10 | 0.23 | 22.39 |
| A1 | A2 | 0.1 | 750 | 6540 | 350.27 | 0.23 | 28.57 |
| A | A1 | 0.3 | 100 | 6640 | 355.62 | 0.70 | 88.34 |
| A1 | A | 1 | 450 | 7090 | 379.72 | 2.33 | 335.72 |
| O | A | 0.6 | 0 | 7090 | 379.72 | 1.40 | 201.43 |
| Total technical loss (kW) | | | | | | | 1,000.00 |

Table 10 - Node-wise technical loss for 11 kV Plant site feeder

Energy at peak demand for one year = 7,090 x 365 x 24 x 0.98 = 608.66 LU

Energy input on feeder during FY 2017-18 = 237.57 LU

Therefore, load factor = 0.39

$$LLF = 0.8 \times 0.39^2 + 0.2 \times 0.39 = 0.20$$

Thus technical loss = 0.20 x 1000.00 x 365 x 24 = 17.52 LU

% technical loss = 7.37 %

f. 11 kV ADE feeder




Figure 22 - SLD of 11 kV ADE feeder

For each node in the 11 kV network, the technical loss per node is derived as follows:

| Start | End | Length (Ckt km) | DT Capacity (kVA) | Cumulative DT Capacity (kVA) | Peak current (A) @ 0.96 pf | Resistance (Ohms) | I ² R (W) |
|-------|-----|-----------------|-------------------|------------------------------|----------------------------|-------------------|----------------------|
| I | J | 0.60 | 200 | 200 | 10.93 | 1.40 | 0.17 |
| H | I | 0.10 | 25 | 225 | 12.30 | 0.23 | 0.04 |
| H1 | H | 0.02 | 878 | 1103 | 60.30 | 0.05 | 0.17 |
| G2 | H | 0.20 | 0 | 1103 | 60.30 | 0.47 | 1.69 |
| G1 | G2 | - | 250 | 1353 | 73.97 | - | - |
| G | G1 | 0.40 | 500 | 1853 | 101.31 | 0.93 | 9.56 |
| F | G | 0.20 | 500 | 2353 | 128.65 | 0.47 | 7.71 |
| E | F | 0.10 | 100 | 2453 | 134.11 | 0.23 | 4.19 |
| D | E | 0.40 | 415 | 2868 | 156.80 | 0.93 | 22.90 |

| Start | End | Length (Ckt km) | DT Capacity (kVA) | Cumulative DT Capacity (kVA) | Peak current (A) @ 0.96 pf | Resistance (Ohms) | I ² R (W) |
|----------------------------------|-----|-----------------|-------------------|------------------------------|----------------------------|-------------------|----------------------|
| C1 | D | 2.50 | 500 | 3368 | 184.14 | 5.82 | 197.37 |
| C | C1 | 0.10 | 250 | 3618 | 197.81 | 0.23 | 9.11 |
| B | B1 | 0.10 | 100 | 3718 | 203.28 | 0.23 | 9.62 |
| N1 | N2 | 0.10 | 100 | 3818 | 208.74 | 0.23 | 10.15 |
| N | N1 | 0.10 | 25 | 3843 | 210.11 | 0.23 | 10.28 |
| M | N | 0.40 | 250 | 4093 | 223.78 | 0.93 | 46.64 |
| L | M | 0.10 | 565 | 4658 | 254.67 | 0.23 | 15.10 |
| B | L | 0.60 | 350 | 5008 | 273.80 | 1.40 | 104.73 |
| A | B | 0.25 | 0 | 5008 | 273.80 | 0.58 | 43.64 |
| O | A | 0.25 | 100 | 5108 | 279.27 | 0.58 | 45.40 |
| Total technical loss (kW) | | | | | | | 538.44 |

Table 11 - Node-wise technical loss for 11 kV ADE feeder

Energy at peak demand for one year = 5,108 x 365 x 24 x 0.96 = 429.56 LU

Energy input on feeder during FY 2017-18 = 97.69 LU

Therefore, load factor = 0.23

$$LLF = 0.8 \times 0.23^2 + 0.2 \times 0.23 = 0.09$$

Thus technical loss = 0.09 x 538.44 x 365 x 24 = 4.10 LU

% technical loss = 4.20 %

g. 11 kV Shaktinagar (Jagda) feeder




Figure 23 - SLD of 11 kV Shaktinagar (Jagda) feeder

For each node in the 11 kV network, the technical loss per node is derived as follows:

| Start | End | Length (Ckt km) | DT Capacity (kVA) | Cummulative DT Capacity (kVA) | Peak current (A) @ 0.98 pf | Resistance (Ohms) | I ² R (kW) |
|-------|-----|-----------------|-------------------|-------------------------------|----------------------------|-------------------|-----------------------|
| I | J | 0.30 | 125 | | - | 0.70 | - |
| H | I | 0.10 | 100 | 100 | 5.36 | 0.23 | 0.01 |
| G | H | 0.40 | 100 | 200 | 10.71 | 0.93 | 0.11 |
| G | G1 | 0.10 | 100 | 200 | 10.71 | 0.23 | 0.03 |
| F | G | 0.30 | 0 | 200 | 10.71 | 0.70 | 0.08 |
| E | F | 0.70 | 100 | 300 | 16.07 | 1.63 | 0.42 |
| D | E | 0.20 | 500 | 800 | 42.85 | 0.47 | 0.85 |
| C | C1 | 0.20 | 750 | 1550 | 83.01 | 0.47 | 3.21 |

| Start | End | Length (Ckt km) | DT Capacity (kVA) | Cummulative DT Capacity (kVA) | Peak current (A) @ 0.98 pf | Resistance (Ohms) | I ² R (kW) |
|----------------------------------|-----|-----------------|-------------------|-------------------------------|----------------------------|-------------------|-----------------------|
| C | D | 0.30 | 600 | 1400 | 74.98 | 0.70 | 3.93 |
| B | C | 0.20 | 0 | 1400 | 74.98 | 0.47 | 2.62 |
| A | B | 1.50 | 1225 | 2625 | 140.59 | 3.49 | 69.03 |
| O | A | 0.10 | 112 | 2737 | 146.59 | 0.23 | 5.00 |
| Total technical loss (kW) | | | | | | | 85.28 |

Table 12 - Node-wise technical loss for 11 kV Shaktinagar feeder

Energy at peak demand for one year = 2,737 x 365 x 24 x 0.98 = 234.97 LU

Energy input on feeder during FY 2017-18 = 40.38 LU

Therefore, load factor = 0.17

$$LLF = 0.8 \times 0.17^2 + 0.2 \times 0.17 = 0.06$$

Thus technical loss = 0.06 x 85.28 x 365 x 24 = 0.43 LU

% technical loss = 1.06 %

h. 11 kV Power house road feeder

SINGLE LINE DIAGRAM OF 11 KV PH ROAD FEEDER OF 33/11 KV S/S PH ROAD, ROURKELA AS ON Mar'18




Figure 24 - SLD of 11 kV PH road feeder

For each node in the 11 kV network, the technical loss per node is derived as follows:

| Start | End | Length (Ckt km) | DT Capacity (kVA) | Cummulative DT Capacity (kVA) | Peak current (A) @ 0.99 pf | Resistance (Ohms) | I ² R (kW) |
|----------------------------------|-----|-----------------|-------------------|-------------------------------|----------------------------|-------------------|-----------------------|
| E | F | 0.10 | 0 | 0 | - | 0.22 | - |
| D | E | 0.05 | 250 | 250 | 13.25 | 0.11 | 0.02 |
| C | D | 0.15 | 100 | 350 | 18.56 | 0.33 | 0.11 |
| C | C1 | 0.20 | 1400 | 1650 | 87.48 | 0.43 | 3.32 |
| B | C | 0.05 | 0 | 350 | 18.56 | 0.11 | 0.04 |
| A | B | 0.20 | 1000 | 1350 | 71.57 | 0.43 | 2.22 |
| O | A | 0.60 | 350 | 1700 | 90.13 | 1.30 | 10.57 |
| Total technical loss (kW) | | | | | | | 16.28 |

Table 13 - Node-wise technical loss for 11 kV PH road feeder

Energy at peak demand for one year = 1,700 x 365 x 24 x 0.99 = 147.43 LU

Energy input on feeder during FY 2017-18 = 85.28 LU

Therefore, load factor = 0.40

LLF = $0.8 \times 0.40^2 + 0.2 \times 0.40 = 0.21$

Thus technical loss = $0.21 \times 16.28 \times 365 \times 24 = 0.30$ LU

% technical loss = 0.51 %

SUMMARY OF TECHNICAL LOSS FOR SAMPLE FEEDERS

| Sl. No. | Feeder Name | Input Energy in FY 17-18 (LU) | Technical Loss in LU | % technical loss |
|---------|-----------------------|-------------------------------|----------------------|------------------|
| a. | 11 kV DAV feeder | 140.04 | 3.04 | 2.17% |
| b. | 11 kV BC feeder | 74.87 | 0.75 | 1.00% |
| c. | 11 kV Jhirpani feeder | 91.13 | 3.01 | 3.30% |
| d. | 11 kV Nayabazar | 147.30 | 37.38 | 25.38% |
| e. | 11 kV Plant Site road | 237.57 | 17.52 | 7.37% |
| f. | 11 kV ADE feeder | 97.69 | 4.10 | 4.20% |

| Sl. No. | Feeder Name | Input Energy in FY 17-18 (LU) | Technical Loss in LU | % technical loss |
|--|--------------------------|-------------------------------|----------------------|------------------|
| g. | 11 kV Shaktinagar feeder | 40.38 | 0.43 | 1.06% |
| h. | 11 kV Power house feeder | 59.36 | 0.30 | 0.51% |
| Total tech. loss at 11 kV level | | 888.35 | 6.53 | 7.49% |

Table 14 - Summary of technical loss for sample 11 kV feeders

T&D loss for sample Distribution transformers

| Sl. No. | DT Name | Input Energy (kWh) | Sold Energy (kWh) | % Loss |
|---------|-----------------------|--------------------|-------------------|--------|
| a. | DTR-1 DAV Polytech | 8,699 | 8,285 | 4.76 |
| b. | DTR-2 DAV Polytech | 28,000 | 23,847 | 14.83 |
| c. | DTR-3 DAV Chowk | 81,223 | 51,514 | 36.57 |
| d. | DTR-5 L-Block DAV | 42,878 | 35,762 | 16.60 |
| e. | DTR-7 Astaprahi Padia | 25,838 | 22,803 | 11.75 |
| f. | DTR-10 FL-Block DAV | 6,012 | 5,123 | 14.79 |
| g. | DTR-12 Atithibhavan | 19,874 | 16,954 | 14.69 |

Table 15 - T&D loss for sample Distribution transformers

System Reliability Indices

Interruption data collected from 11 kV feeder meters is as follows:

| Sub-Station Name | Feeder Name | 11 kV Feeders Meter No. | Duration of interruption (in mins) | Frequency of interruption (Nos.) | No. of Consumers |
|-------------------|-------------------|-------------------------|------------------------------------|----------------------------------|------------------|
| REC | OSAP | WSC07704 | 2920 | 49 | 3774 |
| | Nayabazar | WSC07685 | 1251 | 21 | 6584 |
| INDUSTRIAL ESTATE | Industrial Estate | ORBS4890 | 13646 | 227 | 3353 |
| PANPOSH | Raw Water | UPB54732 | 4856 | 81 | 1357 |
| | College | UPB54737 | 5513 | 92 | 2868 |
| | Town | ORBS4751 | 6848 | 114 | 3529 |
| | Modern India-II | WSC07576 | 11635 | 194 | 7643 |
| POWER HOUSE | Main Road | WSC32919 | 13404 | 223 | 3255 |
| | Ph. House Road | WES48743 | 10320 | 172 | 1626 |
| | Udit Nagar | WES48745 | 12000 | 200 | 3069 |
| CHEND | Self Finance | WSC39167 | 2627 | 44 | 2203 |
| | Panposh | ORBS4894 | 8513 | 142 | 2572 |
| | RDA | ORBS4763 | 8517 | 142 | 1925 |
| | Chend PH-I | ORBS4777 | 13877 | 231 | 4023 |
| | Kalingavihar | WSC39176 | 4406 | 73 | 2931 |
| BASANTI | Madhusudanp ali | ORBS4756 | 5594 | 93 | 5042 |
| | PHD (Basanti-2) | WSC32995 | 5983 | 100 | 2267 |
| | Basanti-I | WES50444 | 6000 | 100 | 5006 |
| KOELNAGAR | Jhirpani | WES48823 | 6000 | 100 | 2259 |
| | ADE Block | WSC07569 OSE00370 | 6008 | 100 | 3186 |
| | Hamirpur | WSC39113 OSE00958 | 3753.75 | 63 | 1928 |
| VEDVYAS | Gopapali | WSC02440 | 11523 | 192 | 128 |
| | vedvyas | WSC13195 | 6196 | 103 | 555 |

Table 16 - Interruption of supply -data from feeder metering system

SAIFI (System Average Interruption Frequency Index)

The System Average Interruption Frequency Index (SAIFI) is commonly used as a reliability indicator by electric power utilities. SAIFI is the average number of interruptions that a customer would experience over a period of time. It is calculated as-

$$\text{SAIFI} = \frac{\text{Total number of consumer interruptions}}{\text{Number of consumers served}} \quad (\text{in Numbers})$$

SAIFI is measured in units of interruptions per consumer. It is usually measured over the course of a year, and according to IEEE Standard 1366-1998 the median value for North American utilities is approximately 1.10 interruptions per consumer.

Sum-product for no. of interruptions and no. of consumers has been taken and overall SAIFI has been calculated as 123.61.

SAIDI (System Average Interruption Duration Index)

The System Average Interruption Duration Index (SAIDI) is commonly used as a reliability indicator by electric power utilities. SAIDI is the average outage duration for each consumer served over a fixed period of time. It is calculated as-

$$\text{SAIDI} = \frac{\text{Sum of all consumer interruption}}{\text{Number of customers served}} \quad (\text{in Hours})$$

SAIDI is measured in units of time, often minutes or hours. It is usually measured over the course of a year, and according to IEEE Standard 1366-1998 the median value for North American utilities is approximately 1.50 mins.

Sum-product for duration of interruptions and no. of consumers has been taken and overall SAIDI has been calculated as 7416 mins.

Power Quality

Voltage profile

33 KV FEEDERS

| Name of 132/33KV GSS | Name of Feeder | Voltage Level | AVG Voltage | V1 | V2 | V3 |
|----------------------|--------------------------|---------------|-------------|--------|----|--------|
| Rourkela GSS | 33 kV Industrial Estate | 33 kV | 33,560 | 33,519 | NA | 33,600 |
| Rourkela GSS | 33 kV Pilot Project | 33 kV | 33,660 | 33,468 | NA | 33,852 |
| Rourkela GSS | 33 kV Powerhouse feeder | 33 kV | 33,963 | 33,783 | NA | 34,143 |
| Chhend GSS | 33 kV Basanti feeder | 33 kV | 33,546 | 33,627 | NA | 33,465 |
| Chhend GSS | 33 kV Chhend – Koelnagar | 33 kV | 33,567 | 33,624 | NA | 33,510 |

Table 17 - Voltage profile of 33 kV feeders

11 KV FEEDERS

| Name of 33/11KV S/S | Nme of 11KV Feeder | Voltage | AVG Voltage | V1 | V2 | V3 |
|---------------------|----------------------|---------|-------------|--------|--------|--------|
| PH Road | Udit Nagar | 11KV | 10,777 | 10,749 | 10,771 | 10,811 |
| PH Road | Main Road | 11KV | 11,067 | 11,080 | 11,042 | 11,080 |
| PH Road | Power House Road | 11KV | 11,039 | 11,093 | 10,950 | 11,074 |
| PH Road | Plant Site Road | 11KV | 11,151 | 11,259 | 11,213 | 10,982 |
| Basanti | DAV | 11KV | 11,086 | 11,081 | 11,131 | 11,046 |
| Basanti | PHD | 11KV | 10,902 | 10,991 | 10,842 | 10,872 |
| Basanti | MS Palli | 11KV | 11,101 | 11,085 | 11,090 | 11,128 |
| REC | Jagda/Shaktinagar | 11KV | 10,923 | 10,920 | 10,919 | 10,931 |
| REC | Nayabazar Bondamunda | 11KV | 10,846 | 10,849 | NA | 10,842 |
| REC | OSAP | 11KV | 10,791 | 10,788 | NA | 10,794 |
| Koel Nagar | Jhirpani | 11KV | 10,794 | 10,762 | 10,866 | 10,753 |
| Koel Nagar | BC | 11KV | 10,889 | 10,882 | NA | 10,896 |

| Name of 33/11KV S/S | Nme of 11KV Feeder | Voltage | AVG Voltage | V1 | V2 | V3 |
|---------------------|--------------------|---------|-------------|--------|--------|--------|
| Koel Nagar | ADE | 11KV | 10,956 | 10,958 | NA | 10,954 |
| Koel Nagar | Hamirpur | 11KV | 10,935 | 10,955 | 10,945 | 10,904 |
| Chhend | Self Finance | 11KV | 10,959 | 10,904 | 10,968 | 11,005 |
| Chhend | Panposh | 11KV | 10,896 | 10,889 | 10,879 | 10,920 |
| Chhend | RDA | 11KV | 10,937 | 10,941 | 10,919 | 10,951 |
| Chhend | Chend1st Phase | 11KV | 10,383 | 10,394 | 10,369 | 10,387 |
| Chhend | Kalingavihar | 11KV | 10,959 | 10,904 | 10,968 | 11,005 |
| Panposh | PHD | 11KV | 11,138 | 11,144 | 11,132 | 11,140 |
| Panposh | Balughat/RAW WATER | 11KV | 11,017 | 11,073 | 11,014 | 10,965 |
| Panposh | College | 11KV | 11,328 | 11,255 | 11,336 | 11,395 |
| Panposh | Town | 11KV | 11,316 | 11,310 | 11,296 | 11,341 |
| Panposh | RGH | 11KV | 11,303 | 11,338 | 11,283 | 11,289 |
| Pilot Project | Pilot Project | 11KV | 11,424 | 11,450 | 11,436 | 11,386 |
| Industrial Estate | Industrial Estate | 11KV | 10,453 | 10,456 | 10,446 | 10,456 |
| Industrial Estate | Town | 11KV | 11,086 | 11,058 | NA | 11,113 |
| Lathikata | Morden India-II | 11KV | 10,876 | 10,875 | NA | 10,876 |
| Vedvyas | Vedvyas | 11KV | 10,997 | 11,065 | NA | 10,929 |
| Vedvyas | Gopapali | 11KV | 10,864 | 10,864 | NA | 10,864 |

Table 18 - Voltage profile of 11 kV feeders

Power Factor profile

33 KV FEEDERS

| Name of 132/33KV GSS | Name of Feeder | Voltage Level | AVG PF |
|----------------------|--------------------------------|---------------|--------|
| Rourkela GSS | 33 kV Industrial Estate feeder | 33KV | 0.92 |
| Rourkela GSS | 33 kV Pilot project feeder | 33KV | 0.88 |
| Rourkela GSS | 33 kV Old IDC feeder | 33KV | 0.94 |
| Rourkela GSS | 33 kV Powerhouse | 33KV | 0.96 |
| Chhend GSS | 33 kV Basanti feeder | 33KV | 0.99 |
| Chhend GSS | 33 kV Chhend Koelnagar | 33KV | 0.95 |

Table 19 - Power factor profile of 33 kV feeders

11 KV FEEDERS

| Name of 33/11KV S/S | Nme of 11KV Feeder | Voltage | AVG PF |
|---------------------|-------------------------------|---------|--------|
| Power House Road | 11 kV Udit Nagar feeder | 11KV | 0.89 |
| Power House Road | 11 kV Main Road feeder | 11KV | 0.92 |
| Power House Road | 11 kV Power House Road feeder | 11KV | 0.99 |
| Power House Road | 11 kV Plant Site Road feeder | 11KV | 0.98 |
| Basanti | 11 kV DAV feeder | 11KV | 0.96 |
| Basanti | 11 kV PHD feeder | 11KV | 0.99 |
| Basanti | 11 kV MS Palli feeder | 11KV | 0.84 |
| REC | 11 kV Jagda/Shaktinagar | 11KV | 0.98 |
| REC | 11 kV Nayabazar Bondamunda | 11KV | 0.83 |
| REC | 11 kV OSAP feeder | 11KV | 0.94 |
| Koel Nagar | 11 kV Jhirpani feeder | 11KV | 0.97 |
| Koel Nagar | 11 kV BC feeder | 11KV | 0.95 |
| Koel Nagar | 11 kV ADE feeder | 11KV | 0.96 |

| Name of 33/11KV S/S | Nme of 11KV Feeder | Voltage | AVG PF |
|---------------------|--------------------------------|---------|--------|
| Koel Nagar | 11 kV Hamirpur feeder | 11KV | 0.99 |
| Chhend | 11 kV Self Finance feeder | 11KV | 0.94 |
| Chhend | 11 kV Panposh feeder | 11KV | 0.91 |
| Chhend | 11 kV RDA feeder | 11KV | 0.89 |
| Chhend | 11 kV Chend1st Phase feeder | 11KV | 0.83 |
| Chhend | 11 kV Kalingavihar feeder | 11KV | 0.87 |
| Chhend | 11 kV Luhakera feeder | 11KV | 0.97 |
| Panposh | 11 kV PHD feeder | 11KV | 0.90 |
| Panposh | 11 kV Raw water feeder | 11KV | 0.63 |
| Panposh | 11 kV College feeder | 11KV | 0.98 |
| Panposh | 11 kV Town feeder | 11KV | 0.93 |
| Panposh | 11 kV RGH feeder | 11KV | 1.00 |
| Pilot Project | 11 kV Pilot Project feeder | 11KV | 0.90 |
| Industrial Estate | 11 kV Industrial Estate feeder | 11KV | 0.80 |
| Industrial Estate | 11 kV Town feeder | 11KV | 0.82 |
| Lathikata | 11 kV Modern India-II feeder | 11KV | 0.88 |
| Vedvyas | 11 kV Vedvyas feeder | 11KV | 0.95 |
| Vedvyas | 11 kV Gopapali feeder | 11KV | 0.96 |

Table 20 - Power factor profile of 11 kV feeders

Harmonics profile

Voltage harmonics profile

| Name of 33/11KV S/S | Nme of 11KV Feeder | THD V1 | THD V2 | THD V3 |
|---------------------|--------------------------------|--------|--------|--------|
| Basanti | 11 kV DAV feeder | 2.45 % | 2.58 % | 3.70 % |
| Basanti | 11 kV PHD feeder | 4.30 % | 4.48 % | 4.21 % |
| Koel Nagar | 11 kV Jhirpani feeder | 2.53 % | 1.86 % | 1.66 % |
| Koel Nagar | 11 kV BC feeder | 2.41 % | 2.05 % | 1.73 % |
| Koel Nagar | 11 kV ADE feeder | 1.62 % | 2.04 % | 2.28 % |
| Koel Nagar | 11 kV Hamirpur feeder | 1.84 % | 1.75 % | 2.18 % |
| Chhend | 11 kV Panposh feeder | 2.31 % | 2.00 % | 1.85 % |
| Chhend | 11 kV RDA feeder | 2.48 % | 2.29 % | 1.92 % |
| Chhend | 11 kV Chend1st Phase feeder | 1.70 % | 1.66 % | 1.58 % |
| Chhend | 11 kV Luhakera feeder | 1.79 % | 2.16 % | 3.40 % |
| Panposh | 11 kV Raw water feeder | 1.23 % | 1.73 % | 1.15 % |
| Panposh | 11 kV College feeder | 1.53 % | 1.94 % | 1.52 % |
| Panposh | 11 kV RGH feeder | 1.52 % | 1.70 % | 1.81 % |
| Pilot Project | 11 kV Pilot Project feeder | 1.77 % | 1.35 % | 1.72 % |
| Industrial Estate | 11 kV Industrial Estate feeder | 1.11 % | 0.89 % | 0.73 % |
| Vedvyas | 11 kV Vedvyas feeder | 5.85 % | 5.97 % | 6.55 % |
| Vedvyas | 11 kV Gopapali feeder | 4.23 % | 4.69 % | 4.80 % |

Table 21 - Voltage harmonics profile

CURRENT HARMONICS PROFILE

| Name of 33/11KV S/S | Nme of 11KV Feeder | THD I1 | THD I2 | THD I3 |
|---------------------|-----------------------------|--------|--------|--------|
| Basanti | 11 kV DAV feeder | 4.25 % | 4.60 % | 4.21 % |
| Basanti | 11 kV PHD feeder | 4.48 % | 4.10 % | 4.27 % |
| Koel Nagar | 11 kV Jhirpani feeder | 2.24 % | 1.49 % | 1.93 % |
| Koel Nagar | 11 kV BC feeder | 4.58 % | - | 3.84 % |
| Koel Nagar | 11 kV ADE feeder | 3.77 % | - | 3.84 % |
| Koel Nagar | 11 kV Hamirpur feeder | 4.14 % | 3.63 % | 5.94 % |
| Chhend | 11 kV Panposh feeder | 3.43 % | 3.13 % | 3.31 % |
| Chhend | 11 kV RDA feeder | 3.83 % | 4.86 % | 4.40 % |
| Chhend | 11 kV Chend1st Phase feeder | 3.73 % | 4.08 % | 4.76 % |
| Chhend | 11 kV Luhakera feeder | 4.94 % | 5.12 % | 3.91 % |
| Panposh | 11 kV Raw water feeder | 1.97 % | 1.84 % | 1.92 % |
| Panposh | 11 kV College feeder | 2.67 % | 2.93 % | 3.90 % |
| Panposh | 11 kV RGH feeder | 3.01 % | 4.02 % | 3.70 % |
| Pilot Project | 11 kV Pilot Project feeder | 3.66 % | 4.41 % | 4.29 % |

| Name of 33/11KV S/S | Nme of 11KV Feeder | THD I1 | THD I2 | THD I3 |
|---------------------|--------------------------------|--------|--------|--------|
| Industrial Estate | 11 kV Industrial Estate feeder | 3.45 % | 4.12 % | 3.92 % |
| Vedvyas | 11 kV Vedvyas feeder | 9.01 % | 9.25 % | 9.49 % |
| Vedvyas | 11 kV Gopapali feeder | 3.81 % | 5.88 % | 6.09 % |

Table 22 - Current harmonics profile

Individual results of harmonics test by Zera MT300 equipment are as follows:

a. 11 kV DAV Feeder

| | | |
|--|---------------------|---|
| | ID: WES50444 | Date: 28.03.2019 Time: 10:39:27 <small>ZERA GmbH Type: MT300 No: 50032012</small> |
|--|---------------------|---|

Meter data

Manufacturer:
Manuf-No:
Operator:

Custom-No:
Supplier:

Location

Customer

MT300 adress: DAV

Measured values : Harmonics

| | UB | IB | MM |
|---------------|----------------------|-----------------------|-----------------------|
| Meas settings | 250.0 V | 05.000 A | 4VA |
| U-Ratio | 1.0/1.0 | | |
| I-Ratio | 1.000/1.000 | | |
| | Actual Values | Meter-Constant | Meter-Register |
| Ratio cons. | On | On | On |

Channel Sum

| | Absolute value | Angle |
|----|----------------|------------|
| 0 | 0.034842 % | 0.000000° |
| 1 | 100.000000 % | 0.000000° |
| 2 | 0.060909 % | 23.693344° |
| 3 | 0.481259 % | 1.763153° |
| 4 | 0.148741 % | 38.032532° |
| 5 | 1.858962 % | 23.535400° |
| 6 | 0.050069 % | 50.407898° |
| 7 | 2.332039 % | 39.471699° |
| 8 | 0.058490 % | 37.953400° |
| 9 | 0.161280 % | 13.460876° |
| 10 | 0.046538 % | 23.534668° |
| 11 | 1.964651 % | 19.959930° |
| 12 | 0.114676 % | 13.449097° |
| 13 | 0.627989 % | 21.439741° |

b. 11 kV PHD feeder

| | | |
|--|---------------------|--|
| | ID: WSC32995 | Date: 28.03.2019 Time: 10:29:01 ZERA GmbH Type: MT300 No: 50032995 |
|--|---------------------|--|

Meter data

Manufacturer:
Manuf-No: Custom-No:
Operator: Supplier:

Location**Customer**

MT300 adress: PHD

Measured values : Harmonics

| | UB | IB | MM |
|---------------|----------------------|-----------------------|-----------------------|
| Meas settings | 250.0 V | 05.000 A | 4WA |
| U-Ratio | 1.0/1.0 | | |
| I-Ratio | 1.000/1.000 | | |
| | Actual Values | Meter-Constant | Meter-Register |
| Ratio cons. | On | On | On |

Channel Sum

| | Absolute value | Angle |
|----|----------------|-------------|
| 0 | 0.019884 % | 0.000000 ° |
| 1 | 100.000000 % | 0.000000 ° |
| 2 | 1.450987 % | 5.050613 ° |
| 3 | 40.736702 % | 56.960403 ° |
| 4 | 1.250590 % | 30.651054 ° |
| 5 | 7.370962 % | 37.966797 ° |
| 6 | 0.941063 % | 37.799332 ° |
| 7 | 6.693740 % | 50.391804 ° |
| 8 | 0.582959 % | 41.147598 ° |
| 9 | 3.334228 % | 4.494568 ° |
| 10 | 0.377518 % | 5.449722 ° |
| 11 | 1.618203 % | 7.650635 ° |
| 12 | 0.099293 % | 12.046310 ° |
| 13 | 2.366956 % | 17.379423 ° |

c. 11 kV Jhirpani feeder

| | | |
|--|---------------------|---|
| | ID: WES48823 | Date: 28.03.2019 Time: 18:57:46 ZERA GmbH Type: MT300 Ver: 50032012 |
|--|---------------------|---|

Meter data

Manufacturer:
Manuf-No:
Operator:

Custom-No:
Supplier:

Location**Customer**

MT300 adress: JHIRPANI

Measured values : Harmonics

| | UB | IB | MM |
|---------------|----------------------|-----------------------|-----------------------|
| Meas settings | 250.0 V | 05.000 A | 4WA |
| U-Ratio | 1.0/1.0 | | |
| I-Ratio | 1.000/1.000 | | |
| | Actual Values | Meter-Constant | Meter-Register |
| Ratio cons. | On | On | On |

Channel L3 Sum 1.77 %

| | Absolute value | Angle |
|----|----------------|-------------|
| 0 | 0.047270 % | 0.000000 ° |
| 1 | 100.000000 % | 0.000000 ° |
| 2 | 0.121497 % | 64.749557 ° |
| 3 | 0.205934 % | 25.981033 ° |
| 4 | 0.060502 % | 42.692924 ° |
| 5 | 0.877747 % | 22.151482 ° |
| 6 | 0.013889 % | 20.884850 ° |
| 7 | 1.154003 % | 49.860809 ° |
| 8 | 0.052848 % | 31.003372 ° |
| 9 | 0.208263 % | 9.038063 ° |
| 10 | 0.008701 % | 0.000000 ° |
| 11 | 0.874389 % | 27.627594 ° |
| 12 | 0.016378 % | 7.156006 ° |
| 13 | 0.324292 % | 22.090849 ° |

d. 11 kV BC feeder

| | | |
|--|---------------------|--|
| | ID: WES51231 | Date: 28.03.2019 Time: 18:51:48 ZERA GmbH Type: MT300 No: 50032012 |
|--|---------------------|--|

Meter data

Manufacturer:
Manuf-No:
Operator:

Custom-No:
Supplier:

Location**Customer**

MT300 adress: CBKNGR

Measured values : Harmonics

| | UB | IB | MM |
|---------------|----------------------|-----------------------|-----------------------|
| Meas settings | 250.0 V | 05.000 A | 4MA |
| U-Ratio | 1.0/1.0 | | |
| I-Ratio | 1.000/1.000 | | |
| | Actual Values | Meter-Constant | Meter-Register |
| Ratio cons. | On | On | On |

Channel Sum

| | Absolute value | Angle |
|----|----------------|-------------|
| 0 | 0.016887 % | 0.000000° |
| 1 | 100.000000 % | 0.000000° |
| 2 | 0.269902 % | 36.407364° |
| 3 | 1.223689 % | 103.625183° |
| 4 | 0.018998 % | 72.659241° |
| 5 | 2.832934 % | 13.341782° |
| 6 | 0.121702 % | 53.749607° |
| 7 | 2.266454 % | 38.765724° |
| 8 | 0.161568 % | 7.712055° |
| 9 | 0.415157 % | 15.706955° |
| 10 | 0.123226 % | 8.437729° |
| 11 | 1.018891 % | 15.530758° |
| 12 | 0.025970 % | 17.213066° |
| 13 | 0.511113 % | 11.393831° |

e. 11 kV ADE feeder

| | | |
|--|---------------------|--|
| | ID: WSC07569 | Date: 28.03.2019 Time: 18:44:23 ZERA GmbH Type: MT300 No: 50032012 |
|--|---------------------|--|

Meter data

Manufacturer:
Manuf-No: Custom-No:
Operator: Supplier:

Location**Customer**

MT300 adress: ADESKNGR

Measured values : Harmonics

| | UB | IB | MM |
|---------------|----------------------|-----------------------|-----------------------|
| Meas settings | 250.0 V | 05.000 A | 3MA |
| U-Ratio | 1.0/1.0 | | |
| I-Ratio | 1.000/1.000 | | |
| | Actual Values | Meter-Constant | Meter-Register |
| Ratio cons. | On | On | On |

Channel Sum

| | Absolute value | Angle |
|----|----------------|-------------|
| 0 | 0.032644 % | 0.000000° |
| 1 | 100.000000 % | 0.000000° |
| 2 | 0.126288 % | 160.554596° |
| 3 | 1.301910 % | 94.246521° |
| 4 | 0.080625 % | 48.795013° |
| 5 | 3.042521 % | 20.110321° |
| 6 | 0.060495 % | 49.291077° |
| 7 | 1.716606 % | 32.801899° |
| 8 | 0.115256 % | 34.653564° |
| 9 | 0.104711 % | 1.996613° |
| 10 | 0.046970 % | 23.060852° |
| 11 | 1.139781 % | 17.880951° |
| 12 | 0.075585 % | 0.551208° |
| 13 | 0.312098 % | 13.583754° |

f. 11 kV Hamirpur feeder

| | | |
|--|---------------------|---|
| | ID: WEG00023 | Date: 28.03.2019 Time: 18:38:02 <small>ZERA GmbH Type: MT300 No: 50022012</small> |
|--|---------------------|---|

Meter data

Manufacturer:
Manuf-No:
Operator:

Custom-No:
Supplier:

Location**Customer**

MT300 adress: HAMIRPUR

Measured values : Harmonics

| | UB | IB | MM |
|---------------|----------------------|-----------------------|-----------------------|
| Meas settings | 250.0 V | 05.000 A | 4WA |
| U-Ratio | 1.0/1.0 | | |
| I-Ratio | 1.000/1.000 | | |
| | Actual Values | Meter-Constant | Meter-Register |
| Ratio cons. | On | On | On |

Channel Sum

| | Absolute value | Angle |
|----|----------------|-------------|
| 0 | 0.094902 % | 0.000000 ° |
| 1 | 100.000000 % | 0.000000 ° |
| 2 | 0.242336 % | 30.601273 ° |
| 3 | 4.066596 % | 57.634460 ° |
| 4 | 0.082291 % | 88.431152 ° |
| 5 | 2.120742 % | 70.824066 ° |
| 6 | 0.233930 % | 3.869339 ° |
| 7 | 2.471306 % | 26.940647 ° |
| 8 | 0.148014 % | 41.873840 ° |
| 9 | 0.991361 % | 6.566055 ° |
| 10 | 0.357118 % | 11.198425 ° |
| 11 | 0.378390 % | 9.084503 ° |
| 12 | 0.060739 % | 23.099243 ° |
| 13 | 0.777983 % | 27.402052 ° |

g. 11 kV Panposh feeder

| | | |
|--|---------------------|---|
| | ID: WES52805 | Date: 28.03.2019 Time: 16:24:16 <small>ZERA GmbH Type: MT300 No: 50032012</small> |
|--|---------------------|---|

Meter data

Manufacturer:
Manuf-No: Custom-No:
Operator: Supplier:

Location**Customer**

MT300 adress: PANPOSH

Measured values : Harmonics

| | UB | IB | MM |
|---------------|----------------------|-----------------------|-----------------------|
| Meas settings | 250.0 V | 05.000 A | 4WA |
| U-Ratio | 1.0/1.0 | | |
| I-Ratio | 1.000/1.000 | | |
| | Actual Values | Meter-Constant | Meter-Register |
| Ratio cons. | On | On | On |

Channel Sum

| | Absolute value | Angle |
|----|----------------|------------|
| 0 | 0.034555 % | 0.000000° |
| 1 | 100.000000 % | 0.000000° |
| 2 | 0.133594 % | 84.824440° |
| 3 | 1.006621 % | 38.157204° |
| 4 | 0.062358 % | 10.240761° |
| 5 | 1.496788 % | 10.106964° |
| 6 | 0.079870 % | 16.771782° |
| 7 | 2.630152 % | 32.282650° |
| 8 | 0.079476 % | 20.571617° |
| 9 | 0.312122 % | 23.170700° |
| 10 | 0.049310 % | 33.576157° |
| 11 | 0.829714 % | 12.955132° |
| 12 | 0.090736 % | 22.144730° |
| 13 | 0.126702 % | 25.393862° |

| | | |
|--|---------------------|---|
| | ID: ORBS4763 | Date: 28.03.2019 Time: 16:30:58 ZERA GmbH Type: MT300 No.: 50032012 |
|--|---------------------|---|

Meter data

Manufacturer:
Manuf-No: Custom-No:
Operator: Supplier:

Location**Customer**

MT300 adress: RDA

Measured values : Harmonics

| | UB | IB | MM |
|---------------|----------------------|-----------------------|-----------------------|
| Meas settings | 250.0 V | 05.000 A | 4WA |
| U-Ratio | 1.0/1.0 | | |
| I-Ratio | 1.000/1.000 | | |
| | Actual Values | Meter-Constant | Meter-Register |
| Ratio cons. | On | On | On |

Channel Sum

| | Absolute value | Angle |
|----|----------------|-------------|
| 0 | 0.092911 % | 0.000000° |
| 1 | 100.000000 % | 0.000000° |
| 2 | 0.261526 % | 163.723022° |
| 3 | 1.532055 % | 32.111500° |
| 4 | 0.259625 % | 47.456383° |
| 5 | 1.685079 % | 9.242859° |
| 6 | 0.067663 % | 32.352802° |
| 7 | 3.353499 % | 27.076046° |
| 8 | 0.033895 % | 27.933098° |
| 9 | 0.425736 % | 21.350719° |
| 10 | 0.097326 % | 11.581543° |
| 11 | 0.680362 % | 9.782921° |
| 12 | 0.017672 % | 4.375572° |
| 13 | 0.616329 % | 1.790104° |

| | | |
|--|---------------------|--|
| | ID: WES52804 | Date: 28.03.2019 Time: 16:05:47 ZERA GmbH Type: MT300 No: 50032012 |
|--|---------------------|--|

Meter data

Manufacturer:
Manuf-No:
Operator:

Custom-No:
Supplier:

Location**Customer**

MT300 adress: LUHAKERA

Measured values : Harmonics

| | UB | IB | MM |
|---------------|----------------------|-----------------------|-----------------------|
| Meas settings | 250.0 V | 05.000 A | 4VA |
| U-Ratio | 1.0/1.0 | | |
| I-Ratio | 1.000/1.000 | | |
| | Actual Values | Meter-Constant | Meter-Register |
| Ratio cons. | On | On | On |

Channel

Sum

| | Absolute value | Angle |
|----|----------------|-------------|
| 0 | 0.184983 % | 0.000000 ° |
| 1 | 100.000000 % | 0.000000 ° |
| 2 | 0.603426 % | 7.866722 ° |
| 3 | 0.877533 % | 29.672707 ° |
| 4 | 0.075373 % | 37.977894 ° |
| 5 | 0.612877 % | 29.776711 ° |
| 6 | 0.137745 % | 25.574387 ° |
| 7 | 3.302133 % | 43.690746 ° |
| 8 | 0.205843 % | 20.604828 ° |
| 9 | 1.864552 % | 14.907967 ° |
| 10 | 0.077945 % | 4.022797 ° |
| 11 | 1.942009 % | 28.554008 ° |
| 12 | 0.028542 % | 29.082146 ° |
| 13 | 0.581575 % | 9.794096 ° |

| | | |
|--|---------------------|---|
| | ID: ORBS4778 | Date: 28.03.2019 Time: 15:05:34 <small>ZERA GmbH Type: MT300 No. 50032012</small> |
|--|---------------------|---|

Meter data

Manufacturer:
Manuf-No:
Operator:

Custom-No:
Supplier:

Location**Customer**

MT300 adress: PILOT

Measured values : Harmonics

| | UB | IB | MM |
|---------------|----------------------|-----------------------|-----------------------|
| Meas settings | 250.0 V | 05.000 A | 4WA |
| U-Ratio | 1.0/1.0 | | |
| I-Ratio | 1.000/1.000 | | |
| | Actual Values | Meter-Constant | Meter-Register |
| Ratio cons. | On | On | On |

Channel

Sum

| | Absolute value | Angle |
|----|----------------|--------------|
| 0 | 0.341976 % | 0.000000 ° |
| 1 | 100.000000 % | 0.000000 ° |
| 2 | 0.074034 % | 124.239685 ° |
| 3 | 1.207490 % | 84.185608 ° |
| 4 | 0.193111 % | 68.884834 ° |
| 5 | 2.822306 % | 41.428108 ° |
| 6 | 0.071937 % | 0.527092 ° |
| 7 | 0.733613 % | 29.499050 ° |
| 8 | 0.230072 % | 43.201279 ° |
| 9 | 0.490674 % | 3.904625 ° |
| 10 | 0.259119 % | 7.384697 ° |
| 11 | 0.435163 % | 5.345123 ° |
| 12 | 0.187260 % | 20.517105 ° |
| 13 | 0.635779 % | 24.378248 ° |

o. 11 kV Industrial estate feeder

| | | |
|--|---------------------|--|
| | ID: ORBS4890 | Date: 28.03.2019 Time: 15:37:18 ZERA GmbH Type: MT300 No: 50032012 |
|--|---------------------|--|

Meter data

Manufacturer:
Manuf-No:
Operator:

Custom-No:
Supplier:

Location**Customer**

MT300 adress: INDFDR

Measured values : Harmonics

| | UB | IB | MM |
|---------------|----------------------|-----------------------|-----------------------|
| Meas settings | 250.0 V | 05.000 A | 4WA |
| U-Ratio | 1.0/1.0 | | |
| I-Ratio | 1.000/1.000 | | |
| | Actual Values | Meter-Constant | Meter-Register |
| Ratio cons. | On | On | On |

Channel Sum

| | Absolute value | Angle |
|----|----------------|-------------|
| 0 | 0.058349 % | 0.000000 ° |
| 1 | 100.000000 % | 0.000000 ° |
| 2 | 0.247810 % | 12.490112 ° |
| 3 | 0.713037 % | 77.653290 ° |
| 4 | 0.147516 % | 24.770851 ° |
| 5 | 3.271261 % | 0.639694 ° |
| 6 | 0.077837 % | 53.966675 ° |
| 7 | 1.818959 % | 44.927475 ° |
| 8 | 0.221598 % | 6.994080 ° |
| 9 | 0.137223 % | 36.543816 ° |
| 10 | 0.107608 % | 5.837555 ° |
| 11 | 0.754842 % | 28.109699 ° |
| 12 | 0.026396 % | 19.270081 ° |
| 13 | 0.760665 % | 26.646399 ° |

p. 11 kV Ved vyas feeder

| | | |
|--|---------------------|---|
| | ID: WES52829 | Date: 28.03.2019 Time: 14:09:42 ZERA GmbH Type: MT300 Ver: 50032012 |
|--|---------------------|---|

Meter data

Manufacturer:
Manuf-No:
Operator:

Custom-No:
Supplier:

Location**Customer**

MT300 adress: 11KWEDVYAS

Measured values : Harmonics

| | UB | IB | MM |
|---------------|----------------------|-----------------------|-----------------------|
| Meas settings | 250.0 V | 05.000 A | 4MA |
| U-Ratio | 1.0/1.0 | | |
| I-Ratio | 1.000/1.000 | | |
| | Actual Values | Meter-Constant | Meter-Register |
| Ratio cons. | On | On | On |

Channel Sum

| | Absolute value | Angle |
|----|----------------|-------------|
| 0 | 0.657365 % | 0.000000 ° |
| 1 | 100.000000 % | 0.000000 ° |
| 2 | 0.663631 % | 33.067703 ° |
| 3 | 0.823455 % | 29.534765 ° |
| 4 | 0.135109 % | 38.468445 ° |
| 5 | 4.983150 % | 53.855347 ° |
| 6 | 0.192699 % | 49.226563 ° |
| 7 | 6.287161 % | 44.374287 ° |
| 8 | 0.162414 % | 5.019150 ° |
| 9 | 1.480972 % | 38.423096 ° |
| 10 | 0.257110 % | 30.185669 ° |
| 11 | 4.054345 % | 17.820404 ° |
| 12 | 0.585222 % | 17.815643 ° |
| 13 | 0.834630 % | 16.461378 ° |

Transformer failure rate

Rourkela Electrical Division (RED) transformer failure

| Installed | | Failed DTs in FY 2017-18 | | | | | | | | | | | | |
|--------------|------------|--------------------------|----------|----------|----------|----------|----------|-----------|----------|----------|----------|----------|----------|-----------|
| Capacity | Nos. | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Jan | Feb | Mar | Total |
| 10 kVA | 0 | | | | | | | | | | | | | 0 |
| 16 kVA | 210 | | 1 | | 2 | 1 | 4 | 4 | 2 | | 1 | 1 | | 16 |
| 25 kVA | 59 | | | 3 | 1 | 5 | 1 | 8 | 1 | | 3 | | | 22 |
| 63 kVA | 36 | | 2 | | | 1 | | | 2 | | 1 | 1 | | 7 |
| 100 kVA | 142 | 4 | 4 | | 3 | | 3 | 2 | | 2 | | 1 | 1 | 20 |
| 150 kVA | 6 | | | | | | | | | | | | | 0 |
| 160 kVA | 1 | | | | | | | | | | | | | 0 |
| 200 kVA | 12 | | | | 1 | | | | | | | | | 1 |
| 250 kVA | 78 | | | 1 | 1 | 1 | | | | | | | | 3 |
| 300 kVA | 0 | | | | | | | | | | | | | 0 |
| 315 kVA | 19 | | | | | | | | | | | | | 0 |
| 400 kVA | 4 | | | | | | | | | | | | | 0 |
| 500 kVA | 50 | | 1 | | 1 | | | | | | | 1 | | 3 |
| 630 kVA | 6 | | | | | 1 | | | | | | | | 1 |
| 750 kVA | 1 | | | | | | | | | | | | | 0 |
| 1000 kVA | 1 | | | | | | | | | | | | | 0 |
| Total | 625 | 4 | 8 | 4 | 9 | 9 | 8 | 14 | 5 | 2 | 5 | 4 | 1 | 73 |

Total transformers in RED division = 625

No. of failed transformers in 2017-18 = 73 - % failure rate = $73 / 625 = 11.68\%$

However, since 10, 16 and 25 kVA transformers are HVDS single consumer DTs with high failure rate, it might be excluded.

Therefore, % failure rate of RED division = $35 / 625 = 5.60\%$

Rourkela Sadar Electrical Division (RSED) transformer failure

| Installed | | Failed DTs in FY 2017-18 | | | | | | | | | | | | |
|--------------|-------------|--------------------------|----------|----------|-----------|-----------|----------|----------|----------|----------|----------|----------|----------|-----------|
| Capacity | Nos. | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Jan | Feb | Mar | Total |
| 10 kVA | 70 | | | | | | | | | | | | | 0 |
| 16 kVA | 875 | 1 | 1 | 1 | 2 | 12 | 6 | 2 | 1 | 1 | | | 1 | 28 |
| 25 kVA | 898 | | | | 2 | 6 | 1 | 2 | | | 1 | | | 12 |
| 63 kVA | 236 | | | | 1 | | | 1 | | 1 | | | 1 | 4 |
| 100 kVA | 266 | 4 | 1 | | 6 | 1 | | 2 | | | 1 | | | 15 |
| 150 kVA | 4 | | | | | | | | | | | | | 0 |
| 160 kVA | 0 | | | | | | | | | | | | | 0 |
| 200 kVA | 6 | | | | | | | | | | | | | 0 |
| 250 kVA | 74 | | | 1 | | 1 | | | | | | | | 2 |
| 300 kVA | 1 | | | | | | | | | | | | | 0 |
| 315 kVA | 17 | | | | | 2 | | | | | | | | 2 |
| 400 kVA | 2 | | | | | | | | | | | | | 0 |
| 500 kVA | 30 | 3 | | 1 | | | 1 | | | | | 1 | | 6 |
| 630 kVA | 1 | | | | | | | | | | | | | 0 |
| 750 kVA | 0 | | | | | | | | | | | | | 0 |
| 1000 kVA | 0 | | | | | | | | | | | | | 0 |
| Total | 2480 | 8 | 2 | 3 | 11 | 22 | 8 | 7 | 1 | 2 | 2 | 1 | 2 | 69 |

Total transformers in RSED division = 2480

No. of failed transformers in 2017-18 = 69 - % failure rate = $69 / 2480 = 2.78\%$

However, since 10, 16 and 25 kVA transformers are HVDS single consumer DTs with high failure rate, it might be excluded.

Therefore, % failure rate of RSED division = $29 / 2480 = 1.17\%$

Rourkela Sadar Electrical Division (RSED) transformer failure

| Installed | | Failed DTs in FY 2017-18 | | | | | | | | | | | | |
|--------------|-------------|--------------------------|----------|----------|-----------|-----------|----------|----------|----------|----------|----------|----------|----------|-----------|
| Capacity | Nos. | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Jan | Feb | Mar | Total |
| 10 kVA | 70 | | | | | | | | | | | | | 0 |
| 16 kVA | 875 | 1 | 1 | 1 | 2 | 12 | 6 | 2 | 1 | 1 | | | 1 | 28 |
| 25 kVA | 898 | | | | 2 | 6 | 1 | 2 | | | 1 | | | 12 |
| 63 kVA | 236 | | | | 1 | | | 1 | | 1 | | | 1 | 4 |
| 100 kVA | 266 | 4 | 1 | | 6 | 1 | | 2 | | | 1 | | | 15 |
| 150 kVA | 4 | | | | | | | | | | | | | 0 |
| 160 kVA | 0 | | | | | | | | | | | | | 0 |
| 200 kVA | 6 | | | | | | | | | | | | | 0 |
| 250 kVA | 74 | | | 1 | | 1 | | | | | | | | 2 |
| 300 kVA | 1 | | | | | | | | | | | | | 0 |
| 315 kVA | 17 | | | | | 2 | | | | | | | | 2 |
| 400 kVA | 2 | | | | | | | | | | | | | 0 |
| 500 kVA | 30 | 3 | | 1 | | | 1 | | | | | 1 | | 6 |
| 630 kVA | 1 | | | | | | | | | | | | | 0 |
| 750 kVA | 0 | | | | | | | | | | | | | 0 |
| 1000 kVA | 0 | | | | | | | | | | | | | 0 |
| Total | 2480 | 8 | 2 | 3 | 11 | 22 | 8 | 7 | 1 | 2 | 2 | 1 | 2 | 69 |

Total transformers in RSED division = 2480

No. of failed transformers in 2017-18 = 69 - % failure rate = $69 / 2480 = 2.78\%$

However, since 10, 16 and 25 kVA transformers are HVDS single consumer DTs with high failure rate, it might be excluded.

Therefore, % failure rate of RSED division = $29 / 2480 = 1.17\%$

Total transformer failure for FY 2017-18

| Installed | | Failed DTs in FY 2017-18 | | | | | | | | | | | | |
|--------------|-------------|--------------------------|-----------|----------|-----------|-----------|-----------|-----------|----------|----------|----------|----------|----------|------------|
| Capacity | Nos. | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Jan | Feb | Mar | Total |
| 10 kVA | 70 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 16 kVA | 1085 | 1 | 2 | 1 | 4 | 13 | 10 | 6 | 3 | 1 | 1 | 1 | 1 | 44 |
| 25 kVA | 957 | 0 | 0 | 3 | 3 | 11 | 2 | 10 | 1 | 0 | 4 | 0 | 0 | 34 |
| 63 kVA | 272 | 0 | 2 | 0 | 1 | 1 | 0 | 1 | 2 | 1 | 1 | 1 | 1 | 11 |
| 100 kVA | 408 | 8 | 5 | 0 | 9 | 1 | 3 | 4 | 0 | 2 | 1 | 1 | 1 | 35 |
| 150 kVA | 10 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 160 kVA | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 200 kVA | 18 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1 |
| 250 kVA | 152 | 0 | 0 | 2 | 1 | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 5 |
| 300 kVA | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 315 kVA | 36 | 0 | 0 | 0 | 0 | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2 |
| 400 kVA | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 500 kVA | 80 | 3 | 1 | 1 | 1 | 0 | 1 | 0 | 0 | 0 | 0 | 2 | 0 | 9 |
| 630 kVA | 7 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1 |
| 750 kVA | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 1000 kVA | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Total | 3105 | 12 | 10 | 7 | 20 | 31 | 16 | 21 | 6 | 4 | 7 | 5 | 3 | 142 |

Total transformers in Smart city area = 3105

No. of failed transformers in 2017-18 = 142 - % failure rate = $142 / 3105 = 4.57\%$

However, since 10, 16 and 25 kVA transformers are HVDS single consumer DTs with high failure rate, it might be excluded.

Therefore, % failure rate = $64 / 3105 = 2.06\%$