

**Amendment No. 3 dated 19.09.2022**

to

**RFP documents for selection of Transmission Service Provider through tariff based competitive bidding process to establish transmission system for “Transmission system for evacuation of power from REZ in Rajasthan (20 GW) under phase III - Part A3”**

S. No.	Existing Provisions			Revised Provisions		
1.	<b>Request for Proposal Notification S. No. 2 &amp; Clause 1.2 of the RFP Document and Schedule-1 (b) of TSA</b>			<b>Request for Proposal Notification S. No. 2 &amp; Clause 1.2 of the RFP Document and Schedule-1 (b) of TSA</b>		
	S. No.	Name of Transmission Element	Scheduled COD in months from Effective Date	S. No.	Name of Transmission Element	Scheduled COD in months from Effective Date
	1.	Fatehgarh 3- Bhadla-3 400kV D/c line (Quad) along with 50 MVAR Switchable line reactor for each circuit at both ends of Fatehgarh 3- Bhadla-3 400 kV D/C line <ul style="list-style-type: none"> <li>400 kV 50 MVAR Switchable line reactor – 4 nos.</li> <li>Switching equipment for 400 kV 50 MVAR switchable line reactor –4 nos.</li> <li>400kV line bays Bhadla-3 S/s &amp; Fatehgarh-3 S/s -4 nos. (2+2)</li> </ul>	.....	1.	Fatehgarh 3- Bhadla-3 400kV D/c line (Quad) along with <b>63 MVAR</b> Switchable line reactor for each circuit at both ends of Fatehgarh 3- Bhadla-3 400 kV D/C line <ul style="list-style-type: none"> <li>400 kV <b>63 MVAR</b> Switchable line reactor – 4 nos.</li> <li>Switching equipment for 400 kV <b>63 MVAR</b> switchable line reactor –4 nos.</li> <li>400kV line bays Bhadla-3 S/s &amp; Fatehgarh-3 S/s -4 nos. (2+2)</li> </ul>	.....
	Note: .....			Note: .....		
2.	<b>Clause No. 2.6.1 of RFP &amp; Schedule 2 of TSA</b>			<b>Clause No. 2.6.1 of RFP &amp; Schedule 2 of TSA</b>		
	S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	
	1.	Fatehgarh 3- Bhadla-3 400kV D/C line (Quad) along with 50 MVAR Switchable line reactor for each circuit at both ends of Fatehgarh 3- Bhadla-3 400kV D/C line	.....	.....		
	1.	Fatehgarh 3- Bhadla-3 400kV D/C line (Quad) along with <b>63 MVAR</b> Switchable line reactor for each circuit at both ends of Fatehgarh 3- Bhadla-3	.....	.....		

S. No.	Existing Provisions				Revised Provisions																								
					400kV D/C line																								
3.	<b>Schedule 5 of TSA</b> <table><tr><th>S. No.</th><th>Name of the Transmission Element</th><th colspan="2">Percentage of Total Transmission Charges payable to the TSP on Commissioning/COD of the Element</th></tr><tr><td>1.</td><td>Fatehgarh 3- Bhadla-3 400kV D/C line (Quad) along with 50 MVar Switchable line reactor for each circuit at both ends of Fatehgarh 3- Bhadla-3 400kV D/C line</td><td colspan="2">.....</td></tr></table>				S. No.	Name of the Transmission Element	Percentage of Total Transmission Charges payable to the TSP on Commissioning/COD of the Element		1.	Fatehgarh 3- Bhadla-3 400kV D/C line (Quad) along with 50 MVar Switchable line reactor for each circuit at both ends of Fatehgarh 3- Bhadla-3 400kV D/C line	.....		<b>Schedule 5 of TSA</b> <table><tr><th>S. No.</th><th>Name of the Transmission Element</th><th colspan="3">Percentage of Total Transmission Charges payable to the TSP on Commissioning/COD of the Element</th></tr><tr><td>1.</td><td>Fatehgarh 3- Bhadla-3 400kV D/C line (Quad) along with <b>63 MVar</b> Switchable line reactor for each circuit at both ends of Fatehgarh 3- Bhadla-3 400kV D/C line</td><td colspan="3">.....</td></tr></table>					S. No.	Name of the Transmission Element	Percentage of Total Transmission Charges payable to the TSP on Commissioning/COD of the Element			1.	Fatehgarh 3- Bhadla-3 400kV D/C line (Quad) along with <b>63 MVar</b> Switchable line reactor for each circuit at both ends of Fatehgarh 3- Bhadla-3 400kV D/C line	.....				
S. No.	Name of the Transmission Element	Percentage of Total Transmission Charges payable to the TSP on Commissioning/COD of the Element																											
1.	Fatehgarh 3- Bhadla-3 400kV D/C line (Quad) along with 50 MVar Switchable line reactor for each circuit at both ends of Fatehgarh 3- Bhadla-3 400kV D/C line	.....																											
S. No.	Name of the Transmission Element	Percentage of Total Transmission Charges payable to the TSP on Commissioning/COD of the Element																											
1.	Fatehgarh 3- Bhadla-3 400kV D/C line (Quad) along with <b>63 MVar</b> Switchable line reactor for each circuit at both ends of Fatehgarh 3- Bhadla-3 400kV D/C line	.....																											
4.	<b>ANNEXURE 8 -UNDERTAKING AND DETAILS OF EQUITY INVESTMENT</b> <b>Format 1: Bidders' Undertakings</b> ..... 8. We confirm that our Bid meets the Scheduled COD of each transmission Element and the Project as specified below: <table><tr><th>S. No.</th><th>Name of the Transmission Element</th><th>Scheduled COD in months from Effective Date</th><th>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</th><th>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</th></tr><tr><td>1.</td><td>Fatehgarh 3- Bhadla-3 400kV D/C line (Quad) along with 50 MVar Switchable line reactor for each circuit at both ends of</td><td>.....</td><td>.....</td><td></td></tr></table>				S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	1.	Fatehgarh 3- Bhadla-3 400kV D/C line (Quad) along with 50 MVar Switchable line reactor for each circuit at both ends of	.....	.....		<b>ANNEXURE 8 -UNDERTAKING AND DETAILS OF EQUITY INVESTMENT</b> <b>Format 1: Bidders' Undertakings</b> ..... 8. We confirm that our Bid meets the Scheduled COD of each transmission Element and the Project as specified below: <table><tr><th>S. No.</th><th>Name of the Transmission Element</th><th>Scheduled COD in months from Effective Date</th><th>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</th><th>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</th></tr><tr><td>1.</td><td>Fatehgarh 3- Bhadla-3 400kV D/C line (Quad) along with <b>63 MVar</b> Switchable line reactor for each circuit at both ends of Fatehgarh 3-</td><td>.....</td><td>.....</td><td></td></tr></table>					S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	1.	Fatehgarh 3- Bhadla-3 400kV D/C line (Quad) along with <b>63 MVar</b> Switchable line reactor for each circuit at both ends of Fatehgarh 3-	.....	.....	
S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element																									
1.	Fatehgarh 3- Bhadla-3 400kV D/C line (Quad) along with 50 MVar Switchable line reactor for each circuit at both ends of	.....	.....																										
S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element																									
1.	Fatehgarh 3- Bhadla-3 400kV D/C line (Quad) along with <b>63 MVar</b> Switchable line reactor for each circuit at both ends of Fatehgarh 3-	.....	.....																										

S. No.	Existing Provisions					Revised Provisions				
		Fatehgarh 3- Bhadla-3 400kV D/C line  • 400 kV 50 MVAR Switchable line reactor – 4 nos.  • Switching equipment for 400 kV 50 MVAR switchable line reactor –4 nos.  • 400kV line bays Bhadla-3 S/s & Fatehgarh-3 S/s -4 nos. (2+2)					Bhadla-3 400kV D/C line  • 400 kV <b>63 MVAR</b> Switchable line reactor – 4 nos.  • Switching equipment for 400 kV <b>63 MVAR</b> switchable line reactor –4 nos.  • 400kV line bays Bhadla-3 S/s & Fatehgarh-3 S/s -4 nos. (2+2)			
5.	<b>Annexure-C of RFP and Schedule: 1 of TSA</b> <b>Specific Technical Requirements for Substation</b>  <b>B.2.1 420kV, 3-Phase, Shunt Reactor</b>  50 MVAR, 420 KV, 3-Phase Reactor shall conform to CEA’s “Standard Specifications and Technical Parameters for Transformers and Reactors (66 kV and above)” as amended upto date available on CEA website.					<b>Annexure-C of RFP and Schedule: 1 of TSA</b> <b>Specific Technical Requirements for Substation</b>  <b>B.2.1 420kV, 3-Phase, Shunt Reactor</b>  <b>63 MVAR</b> , 420 KV, 3-Phase Reactor shall conform to CEA’s “Standard Specifications and Technical Parameters for Transformers and Reactors (66 kV and above)” as amended upto date available on CEA website.				