

**Amendment No. 4 dated 03.01.2023**

to

**RFP documents for selection of Transmission Service Provider through tariff based competitive bidding process to establish transmission system for  
“Transmission system for evacuation of power from REZ in Rajasthan (20 GW) under phase III –Part B1”**

S. No.	Existing Provisions	Revised Provisions																								
1.	<p><b>Request for Proposal Notification Sl. No. 2.0 &amp; Clause 1.2 of the RFP Document and Schedule-1 (b) of TSA</b></p> <table><tr><th>S. No.</th><th>Name of Transmission Element</th></tr><tr><td>1.</td><td><p>Establishment of 2x1500 MVA 765/400kV &amp; 3x500 MVA 400/220 kV pooling station at Bhadla-3 along with 2x330 MVar (765kV) Bus Reactor &amp; 2x125 MVar (420kV) Bus Reactor .....</p><p><b>Future provisions:</b> Space for</p><ul style="list-style-type: none"><li>765/400kV ICTs along with bays: 2 nos.</li><li>765kV line bay along with switchable line reactor: 4 nos.</li><li>765kV line bay: 4 nos.</li><li>765kV Bus Reactor along with bays: 2 nos.</li><li>400/220 kV ICTs along with bays: 10 nos.</li><li>400 kV line bays: 8 nos.</li><li>400 kV line bays along with switchable line reactor: 4 Nos.</li><li>400kV Bus Reactor along with bays: 2 nos.</li><li>400kV Sectionalization bay: 2 nos.</li><li>220 kV line bays: 12 nos.</li><li>220kV sectionalization bay: 2nos.</li></ul></td></tr><tr><td>2.</td><td>.....</td></tr><tr><td>3.</td><td>.....</td></tr><tr><td>4.</td><td>.....</td></tr><tr><td>5.</td><td>.....</td></tr></table> <p>.....</p>	S. No.	Name of Transmission Element	1.	<p>Establishment of 2x1500 MVA 765/400kV &amp; 3x500 MVA 400/220 kV pooling station at Bhadla-3 along with 2x330 MVar (765kV) Bus Reactor &amp; 2x125 MVar (420kV) Bus Reactor .....</p> <p><b>Future provisions:</b> Space for</p> <ul style="list-style-type: none"><li>765/400kV ICTs along with bays: 2 nos.</li><li>765kV line bay along with switchable line reactor: 4 nos.</li><li>765kV line bay: 4 nos.</li><li>765kV Bus Reactor along with bays: 2 nos.</li><li>400/220 kV ICTs along with bays: 10 nos.</li><li>400 kV line bays: 8 nos.</li><li>400 kV line bays along with switchable line reactor: 4 Nos.</li><li>400kV Bus Reactor along with bays: 2 nos.</li><li>400kV Sectionalization bay: 2 nos.</li><li>220 kV line bays: 12 nos.</li><li>220kV sectionalization bay: 2nos.</li></ul>	2.	.....	3.	.....	4.	.....	5.	.....	<p><b>Request for Proposal Notification Sl. No. 2.0 &amp; Clause 1.2 of the RFP Document and Schedule-1 (b) of TSA</b></p> <table><tr><th>S. No.</th><th>Name of Transmission Element</th></tr><tr><td>1.</td><td><p>Establishment of 2x1500 MVA 765/400kV &amp; 3x500 MVA 400/220 kV pooling station at Bhadla-3 along with 2x330 MVar (765kV) Bus Reactor &amp; 2x125 MVar (420kV) Bus Reactor.....</p><p><b>Future provisions:</b> Space for</p><ul style="list-style-type: none"><li>765/400kV ICTs along with bays: 2 nos.</li><li><b>765kV line bay along with switchable line reactor: 6 nos.</b></li><li>765kV line bay: 4 nos.</li><li>765kV Bus Reactor along with bays: 2 nos.</li><li>400/220 kV ICTs along with bays: 10 nos.</li><li>400 kV line bays: 8 nos.</li><li><b>400 kV line bays along with switchable line reactor: 6 Nos.</b></li><li>400kV Bus Reactor along with bays: 2 nos.</li><li>400kV Sectionalization bay: 2 nos.</li><li>220 kV line bays: 12 nos.</li><li>220kV sectionalization bay: 2nos.</li></ul></td></tr><tr><td>2.</td><td>.....</td></tr><tr><td>3.</td><td>.....</td></tr><tr><td>4.</td><td>.....</td></tr><tr><td>5.</td><td>.....</td></tr></table> <p>.....</p>	S. No.	Name of Transmission Element	1.	<p>Establishment of 2x1500 MVA 765/400kV &amp; 3x500 MVA 400/220 kV pooling station at Bhadla-3 along with 2x330 MVar (765kV) Bus Reactor &amp; 2x125 MVar (420kV) Bus Reactor.....</p> <p><b>Future provisions:</b> Space for</p> <ul style="list-style-type: none"><li>765/400kV ICTs along with bays: 2 nos.</li><li><b>765kV line bay along with switchable line reactor: 6 nos.</b></li><li>765kV line bay: 4 nos.</li><li>765kV Bus Reactor along with bays: 2 nos.</li><li>400/220 kV ICTs along with bays: 10 nos.</li><li>400 kV line bays: 8 nos.</li><li><b>400 kV line bays along with switchable line reactor: 6 Nos.</b></li><li>400kV Bus Reactor along with bays: 2 nos.</li><li>400kV Sectionalization bay: 2 nos.</li><li>220 kV line bays: 12 nos.</li><li>220kV sectionalization bay: 2nos.</li></ul>	2.	.....	3.	.....	4.	.....	5.	.....
S. No.	Name of Transmission Element																									
1.	<p>Establishment of 2x1500 MVA 765/400kV &amp; 3x500 MVA 400/220 kV pooling station at Bhadla-3 along with 2x330 MVar (765kV) Bus Reactor &amp; 2x125 MVar (420kV) Bus Reactor .....</p> <p><b>Future provisions:</b> Space for</p> <ul style="list-style-type: none"><li>765/400kV ICTs along with bays: 2 nos.</li><li>765kV line bay along with switchable line reactor: 4 nos.</li><li>765kV line bay: 4 nos.</li><li>765kV Bus Reactor along with bays: 2 nos.</li><li>400/220 kV ICTs along with bays: 10 nos.</li><li>400 kV line bays: 8 nos.</li><li>400 kV line bays along with switchable line reactor: 4 Nos.</li><li>400kV Bus Reactor along with bays: 2 nos.</li><li>400kV Sectionalization bay: 2 nos.</li><li>220 kV line bays: 12 nos.</li><li>220kV sectionalization bay: 2nos.</li></ul>																									
2.	.....																									
3.	.....																									
4.	.....																									
5.	.....																									
S. No.	Name of Transmission Element																									
1.	<p>Establishment of 2x1500 MVA 765/400kV &amp; 3x500 MVA 400/220 kV pooling station at Bhadla-3 along with 2x330 MVar (765kV) Bus Reactor &amp; 2x125 MVar (420kV) Bus Reactor.....</p> <p><b>Future provisions:</b> Space for</p> <ul style="list-style-type: none"><li>765/400kV ICTs along with bays: 2 nos.</li><li><b>765kV line bay along with switchable line reactor: 6 nos.</b></li><li>765kV line bay: 4 nos.</li><li>765kV Bus Reactor along with bays: 2 nos.</li><li>400/220 kV ICTs along with bays: 10 nos.</li><li>400 kV line bays: 8 nos.</li><li><b>400 kV line bays along with switchable line reactor: 6 Nos.</b></li><li>400kV Bus Reactor along with bays: 2 nos.</li><li>400kV Sectionalization bay: 2 nos.</li><li>220 kV line bays: 12 nos.</li><li>220kV sectionalization bay: 2nos.</li></ul>																									
2.	.....																									
3.	.....																									
4.	.....																									
5.	.....																									

S. No.	Existing Provisions				Revised Provisions				
2.	<b>ANNEXURE 8 -UNDERTAKING AND DETAILS OF EQUITY INVESTMENT</b>				<b>ANNEXURE 8 -UNDERTAKING AND DETAILS OF EQUITY INVESTMENT</b>				
	<b>Format 1: Bidders' Undertakings</b>				<b>Format 1: Bidders' Undertakings</b>				
	8. We confirm that our Bid meets the Scheduled COD of each transmission Element and the Project as specified below:				8. We confirm that our Bid meets the Scheduled COD of each transmission Element and the Project as specified below:				
S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element
1.	Establishment of 2x1500 MVA 765/400kV & 3x500 MVA 400/220 kV pooling station at Bhadla-3 along with 2x330 MVar (765kV) Bus Reactor & 2x125 MVar (420kV) Bus Reactor ..... <b>Future provisions:</b> Space for • 765/400kV ICTs along with bays: 2 nos. • 765kV line bay	18 months	16.48%	Elements marked at Sl. No. 1, 2, 3, 4 & 5 are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.	1.	Establishment of 2x1500 MVA 765/400kV & 3x500 MVA 400/220 kV pooling station at Bhadla-3 along with 2x330 MVar (765kV) Bus Reactor & 2x125 MVar (420kV) Bus Reactor ..... <b>Future provisions:</b> Space for • 765/400kV ICTs along with bays: 2 nos. • <b>765kV line bay</b>	18 months	16.48%	Elements marked at Sl. No. 1, 2, 3, 4 & 5 are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.

S. No.	Existing Provisions					Revised Provisions				
		along with switchable line reactor: 4 nos. • 765kV line bay: 4 nos. • 765kV Bus Reactor along with bays: 2 nos. • 400/220 kV ICTs along with bays: 10 nos. • 400 kV line bays: 8 nos. • 400 kV line bays along with switchable line reactor: 4 Nos. • 400kV Bus Reactor along with bays: 2 nos. • 400kV Sectionalization bay: 2 nos. • 220 kV line bays: 12 nos. • 220kV sectionalization bay: 2nos.					<b>along with switchable line reactor: 6 nos.</b> • 765kV line bay: 4 nos. • 765kV Bus Reactor along with bays: 2 nos. • 400/220 kV ICTs along with bays: 10 nos. • 400 kV line bays: 8 nos. • <b>400 kV line bays along with switchable line reactor: 6 Nos.</b> • 400kV Bus Reactor along with bays: 2 nos. • 400kV Sectionalization bay: 2 nos. • 220 kV line bays: 12 nos. • 220kV sectionalization bay: 2nos.			
	2.	.....				2.	.....			
	3.	.....				3.	.....			
	4.	.....				4.	.....			
	5.	.....				5.	.....			