

Amendment No. 2 dated 11.03.2024

to

RFP documents for selection of Transmission Service Provider through tariff based competitive bidding process to establish transmission system for “Transmission system for evacuation of power from Rajasthan REZ Ph -IV (Part-2: 5.5 GW) (Jaisalmer/Barmer Complex) Part D”

Sl. No.	Existing Provisions	Revised Provisions																						
1.	<p>Request for Proposal Notification Sl. No. 2 & Clause 1.2 of the RFP Document and Schedule-1 (b) of TSA</p> <table><tr><th colspan="3">Transmission system for evacuation of power from Rajasthan REZ Ph-IV (Part-2 :5.5 GW) (Jaisalmer/Barmer Complex) Part D</th></tr><tr><th>S. N o.</th><th>Name of Transmission Element</th><th>Scheduled COD in months from Effective Date</th></tr><tr><td>1.</td><td>Beawar- Mandsaur PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end<ul style="list-style-type: none">----Switching equipment for 765 kV, 240 MVAR switchable line reactors at Mandsaur PS – 2 Nos.</td><td rowspan="2">24 Months</td></tr><tr><td>2.</td><td>---</td></tr></table>	Transmission system for evacuation of power from Rajasthan REZ Ph-IV (Part-2 :5.5 GW) (Jaisalmer/Barmer Complex) Part D			S. N o.	Name of Transmission Element	Scheduled COD in months from Effective Date	1.	Beawar- Mandsaur PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end <ul style="list-style-type: none">----Switching equipment for 765 kV, 240 MVAR switchable line reactors at Mandsaur PS – 2 Nos.	24 Months	2.	---	<p>Request for Proposal Notification Sl. No. 2 & Clause 1.2 of the RFP Document and Schedule-1 (b) of TSA</p> <table><tr><th colspan="3">Transmission system for evacuation of power from Rajasthan REZ Ph-IV (Part-2 :5.5 GW) (Jaisalmer/Barmer Complex) Part D</th></tr><tr><th>S. No.</th><th>Name of Transmission Element</th><th>Scheduled COD in months from Effective Date</th></tr><tr><td>1.</td><td>Beawar- Mandsaur PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end<ul style="list-style-type: none">---Switching equipment for 765 kV, 240 MVAR switchable line reactors at Mandsaur PS – 2 Nos.Spare Reactor (1-ph, 1x80 MVA) unit at 765/400 kV Beawar S/s</td><td rowspan="2">24 Months</td></tr><tr><td>2.</td><td>---</td></tr></table>	Transmission system for evacuation of power from Rajasthan REZ Ph-IV (Part-2 :5.5 GW) (Jaisalmer/Barmer Complex) Part D			S. No.	Name of Transmission Element	Scheduled COD in months from Effective Date	1.	Beawar- Mandsaur PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end <ul style="list-style-type: none">---Switching equipment for 765 kV, 240 MVAR switchable line reactors at Mandsaur PS – 2 Nos.Spare Reactor (1-ph, 1x80 MVA) unit at 765/400 kV Beawar S/s	24 Months	2.	---
Transmission system for evacuation of power from Rajasthan REZ Ph-IV (Part-2 :5.5 GW) (Jaisalmer/Barmer Complex) Part D																								
S. N o.	Name of Transmission Element	Scheduled COD in months from Effective Date																						
1.	Beawar- Mandsaur PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end <ul style="list-style-type: none">----Switching equipment for 765 kV, 240 MVAR switchable line reactors at Mandsaur PS – 2 Nos.	24 Months																						
2.	---																							
Transmission system for evacuation of power from Rajasthan REZ Ph-IV (Part-2 :5.5 GW) (Jaisalmer/Barmer Complex) Part D																								
S. No.	Name of Transmission Element	Scheduled COD in months from Effective Date																						
1.	Beawar- Mandsaur PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end <ul style="list-style-type: none">---Switching equipment for 765 kV, 240 MVAR switchable line reactors at Mandsaur PS – 2 Nos.Spare Reactor (1-ph, 1x80 MVA) unit at 765/400 kV Beawar S/s	24 Months																						
2.	---																							

Sl. No.	Existing Provisions					Revised Provisions				
2.	Clause No. 2.6.1 of RFP & Schedule 2 of TSA & Annexure 8					Clause No. 2.6.1 of RFP & Schedule 2 of TSA				
	Sl. No.	Name of the Transmission Element	Scheduled COD	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	Sl. No.	Name of the Transmission Element	Scheduled COD	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element
	1.	Beawar- Mandsaur PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end (260 km) • -- • Switching equipment for 765 kV, 240 MVAR switchable line reactors at Mandsaur PS – 2 Nos	---	---	---	1.	Beawar- Mandsaur PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end (260 km) • --- • Switching equipment for 765 kV, 240 MVAR switchable line reactors at Mandsaur PS – 2 Nos • Spare Reactor (1-ph, 1x80 MVA _r) unit at 765/400 kV Beawar S/s	---	---	---
	2.	---					---			

Sl. No.	Existing Provisions		Revised Provisions	
3.	Schedule 5 of TSA		Schedule 5 of TSA	
	S. No.	Name of the Transmission Element	S. No.	Name of the Transmission Element
		Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project		Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project
	1.	Beawar- Mandsaur PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end (260 kM) <ul style="list-style-type: none"> -- Switching equipment for 765 kV, 240 MVAR switchable line reactors at Mandsaur PS – 2 Nos 	1.	Beawar- Mandsaur PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end (260 kM) <ul style="list-style-type: none"> --- Switching equipment for 765 kV, 240 MVAR switchable line reactors at Mandsaur PS – 2 Nos Spare Reactor (1-ph, 1x80 MVAR) unit at 765/400 kV Beawar S/s
	2.	---	2.	---